



Time
00:00:00

Event Type
Alarm Active

Device Message / Location
AUDITORIUM BEAM DETECTOR
FLOOR 1

Active points
A001

Disabled points
D000

Addressable
Loop Return
Addressable
Loop Feed

Horn / Strobe
Circuit
Exterior Beacon
Circuit

To Battery

REV.	DESCRIPTION	DATE	DRWN:	FW'D:
0	Original Issue	4/13	DH	TD

R.B. Allen
Co., Inc.

EST
ELECTRONIC SYSTEM TECHNOLOGY

P.O. BOX 770
131 LAFAYETTE RD
NO. WASHINGTON NH 03602
1-603-258-7264

DWG NAME:
**UNE - Ludcke Auditorium
Portland, Maine
Fire Alarm Annunciator Layout**

DWG No: FA-002