Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 07/30/13

UNE - Ludcke Auditorium
Portland, Maine

Click Here to Ret
Bill of Material/Ir

System Narrative

In the event of an alarm from an actuated device, the following shall occur: (Devices reporting an alarm: Manual Station, Smoke Detector, Heat Detector, or Beam Detector)

1) Notify the Fire Department via the Radio Master Box;
Notify Campus Security via Digital Communicator (DACT) and Central Station

2) Annunciate audibly,visually, and in plain english the active initiating device at the Fire Alarm Control Panel

3) Activate the exerior Strobe/Beacon

4) Flash all strobe appliance circuits in a synchronized manner until the FACP has been reset.

5) Sound a Temporal Code 3 on all horn units until silenced. If Silenced, the evacuation tone shall resound.

In the event of a supervisory condition from an actuated device, the following shall occur:

1) Notify Campus Security via Digital Communicator (DACT) and Central Station

2) Annunciate audibly,visually, and in plain english the active initiating device at the Fire Alarm Control Panel

In the event of a system trouble report, the following shall occur:

1) Notify Campus Security via Digital Communicator (DACT) and Central Station

2) Annunciate audibly,visually, and in plain english the active initiating device at the Fire Alarm Control Panel