



- OH — OVERHEAD WIRING, TYPE AS INDICATED
- UG --- UNDERGROUND OR UNDERSLAB WIRING
- ○ UTILITY POLE
- ⊞ FUSED DISCONNECT SWITCH
- NON-FUSED DISCONNECT SWITCH
- ⊥ GROUNDING SYSTEM
- ⊞ JUNCTION BOX, IN-GROUND
- ⊞ ELECTRICAL MANHOLE, COORDINATE LOCATION WITH OTHER UNDERGROUND UTILITIES
- ⊞ PADMOUNT TRANSFORMER
- ⊞ ELECTRICAL MANHOLE - 38Y IN ACCORDANCE WITH UTILITY STANDARDS
- ⊞ PEDESTAL LOCATION, PEDESTAL BY SERVICE PROVIDER, STUB UP (2) 2" CONDUITS WITH CONNECTORS AND BUSHINGS FROM HANDHOLE
- ⊞ HANDHOLE, MINIMUM 18"x36"x24", SIZE PER NEC FOR NUMBER OF CONDUITS INSTALLED
- ⊞ METER & CT CABINET, PEDESTAL MOUNTED
- ○ SINGLE POLE MOUNTED LIGHT
- ○ ○ DOUBLE POLE MOUNTED LIGHT
- ← SINGLE POLE HOMERUN: (2)#12+(1)#12G UNO, CONNECT TO PANEL INDICATED
- ← SINGLE-PHASE HOMERUN OR MULTIPLE HOMERUN UTILIZING THE SAME CONDUIT, CONNECT TO PANEL INDICATED
- ← 3-PHASE HOMERUN OR MULTIPLE HOMERUN UTILIZING THE SAME CONDUIT, CONNECT TO PANEL INDICATED

E9 LEGEND

65 NEWBURY STREET
 PORTLAND, ME 04101
 207.761.9000
 info@portcityarch.com
 WWW.PORTCITYARCH.COM

Allied Engineering
 Structural Mechanical
 Electrical Commissioning

160 Veranda Street
 Portland, Maine 04103
 T: 207.221.2260
 F: 207.221.2266
 Web: www.allied-eng.com

ALLIED PROJECT No: 14088
 Graphic Scale:

REVISIONS		
No.	Description	Date

PERMIT SET

UNIVERSITY OF NEW ENGLAND
 PORTLAND, MAINE

ALUMNI HALL RENOVATION

PARTIAL SITE PLAN AND DETAILS

Project Number **14525**
 Date **May 1, 2015**
 Drawn by **DLL**
 Checked by **SRM**

ES1.1
 Scale AS NOTED

N:\Projects\2014\14088 - UNE - Alumni Hall\DD Drawing Files\14088_ES.dwg May 01, 2015 - 9:16am