

... **Fire Protection by Computer Design**

EASTERN FIRE PROTECTION
AUBURN, ME
207-784-1507

Job Name : UNE ALUMNI HALL RENOVATIONS
Drawing : 2 OF 2
Location : PORTLAND, MAINE
Remote Area : ATTIC EXISTING
Contract : AU-5342-15
Data File : 5342 UNE ALUMNI HALL ATTIC EXISTING.WXF

HYDRAULIC CALCULATIONS
for

Project name: UNE ALUMNI HALL RENOVATIONS
Location: PORTLAND, MAINE
Drawing no: 2 OF 2
Date: 11-12-15

Design

Remote area number: ATTIC EXISTING
Remote area location: ATTIC EXISTING
Occupancy classification: LIGHT HAZARD
Density: .1 - Gpm/SqFt
Area of application: 2425 - SqFt
Coverage per sprinkler: 120 - SqFt
Type of sprinklers calculated: RELIABLE FIFR K5.6 UPRIGHT
No. of sprinklers calculated: 47
In-rack demand: - GPM
Hose streams: 100 - GPM
Total water required (including hose streams): 625.631 - GPM @ 47.449 - Psi
Type of system: DRY
Volume of dry or preaction system: 148 - Gal

Water supply information

Date: 06-06-2012
Location: SEE PLOT PLAN DWG 1 OF 2
Source: PORTLAND WATER DISTRICT

Name of contractor: EASTERN FIRE PROTECTION
Address: AUBURN, ME
Phone number: 207-784-1507
Name of designer: GRD
Authority having jurisdiction: MAINE STATE FIRE MARSHAL
Notes: (Include peaking information or gridded systems here.)

Water Supply Curve C


EASTERN FIRE PROTECTION
 UNE ALUMNI HALL RENOVATIONS

City Water Supply:

C1 - Static Pressure : 56
 C2 - Residual Pressure: 54
 C2 - Residual Flow : 1034

Demand:

D1 - Elevation : 15.158
 D2 - System Flow : 525.631
 D2 - System Pressure : 47.449
 Hose (Demand) : 100
 D3 - System Demand : 625.631
 Safety Margin : 7.761



Fittings Used Summary

EASTERN FIRE PROTECTION
UNE ALUMNI HALL RENOVATIONS

Fitting Legend Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
Dge	Dry Gem DPV-1							2.2	4.9		8.9		22								
E	NFPA 13 90° Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
I	90° Grid-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40
T	NFPA 13 90° Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zma	Maxim M200 Horz Butt																				

Fitting generates a Fixed Loss Based on Flow

Units Summary

- Diameter Units Inches
- Length Units Feet
- Flow Units US Gallons per Minute
- Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	56.0	54	1034.0	55.21	625.63	47.449

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
SP01	0.0	5.6	7.0	14.82	
400	130.0	5.6	7.67	15.51	
401	130.0	5.6	7.7	15.54	
402	130.0	5.6	7.87	15.71	
403	130.0	5.6	8.09	15.93	
404	130.0	5.6	8.48	16.31	
405	130.0	5.6	7.0	14.82	
406	130.0	5.6	7.03	14.84	
407	130.0	5.6	7.18	15.01	
408	130.0	5.6	7.39	15.22	
409	130.0	5.6	7.75	15.58	
410	130.0	5.6	8.29	16.13	
411	130.0		9.43		
412	137.0	5.6	7.8	15.64	
413	137.0	5.6	7.83	15.67	
414	137.0	5.6	7.94	15.78	
415	137.0	5.6	8.09	15.93	
416	137.0	5.6	8.12	15.96	
417	137.0		8.29		
420	130.0	5.6	10.26	17.94	
421	130.0	5.6	10.3	17.97	
422	130.0	5.6	10.52	18.16	
423	130.0	5.6	10.85	18.45	
424	130.0	5.6	11.29	18.82	
425	138.0	5.6	7.69	15.53	
426	138.0	5.42	7.56	14.89	K=K @ EQ01
427	138.0		8.15		
428	138.0	5.6	7.91	15.75	
429	138.0		8.8		
430	130.0	5.6	10.42	18.08	
431	130.0	5.6	10.46	18.11	
432	130.0	5.6	10.68	18.3	
433	130.0	5.6	10.97	18.55	
434	130.0	5.6	11.42	18.92	
435	138.0	5.6	7.86	15.7	
436	138.0	5.42	7.67	15.01	K=K @ EQ01
437	138.0		8.27		
438	138.0	5.6	8.04	15.88	
439	138.0		8.94		

NODE ANALYSIS (cont.)

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
460	128.0		13.35		
461	128.0		13.48		
462	128.0		13.79		
463	128.0		13.8		
464	128.0		13.95		
465	128.0		13.94		
466	128.0		13.95		
467	128.0		14.11		
475	130.0		15.86		
175	112.0		24.83		
075	96.5		35.52		
DPV	95.0		36.61		
BOR1	93.0		38.17		
BFP	92.0		38.97		
BASE	92.0		42.45		
UG1	95.0		41.84	100.0	
TEST	95.0		47.45		

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
SP01 to EQ01	0 0	5.60	14.82 14.82	1 1.049	T	3.568 0.0 0.0	1.000 3.568 4.568	100 7.000 0.0 0.478		Vel = 5.50	
EQ01			0.0 14.82					7.478		K Factor = 5.42	
400 to 401	130 130	5.60	15.51 15.51	2 2.067		0.0 0.0 0.0	7.000 0.0 7.000	100 7.669 0.0 0.029		Vel = 1.48	
401 to 402	130 130	5.60	15.54 31.05	2 2.067	E	3.568 0.0 0.0	7.500 3.568 11.068	100 7.698 0.0 0.168		Vel = 2.97	
402 to 403	130 130	5.60	15.70 46.75	2 2.067		0.0 0.0 0.0	7.000 0.0 7.000	100 7.866 0.0 0.225		Vel = 4.47	
403 to 404	130 130	5.60	15.93 62.68	2 2.067		0.0 0.0 0.0	7.000 0.0 7.000	100 8.091 0.0 0.389		Vel = 5.99	
404 to 411	130 130	5.60	16.31 78.99	2 2.067	T	7.137 0.0 0.0	4.000 7.137 11.137	100 8.480 0.0 0.947		Vel = 7.55	
411			0.0 78.99					9.427		K Factor = 25.73	
405 to 406	130 130	5.60	14.82 14.82	2 2.067		0.0 0.0 0.0	7.000 0.0 7.000	100 7.000 0.0 0.027		Vel = 1.42	
406 to 407	130 130	5.60	14.84 29.66	2 2.067	E	3.568 0.0 0.0	7.500 3.568 11.068	100 7.027 0.0 0.154		Vel = 2.84	
407 to 408	130 130	5.60	15.01 44.67	2 2.067		0.0 0.0 0.0	7.000 0.0 7.000	100 7.181 0.0 0.207		Vel = 4.27	
408 to 409	130 130	5.60	15.22 59.89	2 2.067		0.0 0.0 0.0	7.000 0.0 7.000	100 7.388 0.0 0.357		Vel = 5.73	
409 to 410	130 130	5.60	15.58 75.47	2 2.067		0.0 0.0 0.0	7.000 0.0 7.000	100 7.745 0.0 0.548		Vel = 7.22	
410 to 411	130 130	5.60	16.13 91.6	2 2.067	T	7.137 0.0 0.0	3.000 7.137 10.137	100 8.293 0.0 1.134		Vel = 8.76	
411 to 460	130 128		78.99 170.59	2 2.067	T	7.137 0.0 0.0	1.500 7.137 8.637	100 9.427 0.866 3.055		Vel = 16.31	
460			0.0 170.59					13.348		K Factor = 46.69	

Final Calculations - Hazen-Williams

EASTERN FIRE PROTECTION
UNE ALUMNI HALL RENOVATIONS

Page 7
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
412 to 413	137 137	5.60	15.64	2		0.0	7.000	100	7.805			
						0.0	0.0		0.0			
413 to 414	137 137	5.60	15.68	2		0.0	7.000	100	7.834			
						0.0	0.0		0.0			
414 to 417	137 137	5.60	15.78	2	T	7.137	3.500	100	7.942			
						0.0	7.137		0.0			
			47.1	2.067		0.0	10.637	0.0327	0.348		Vel = 4.50	
417			0.0 47.10						8.290		K Factor = 16.36	
415 to 416	137 137	5.60	15.93	2		0.0	7.000	100	8.090			
						0.0	0.0		0.0			
416 to 417	137 137	5.60	15.96	2	T	7.137	3.500	100	8.121			
						0.0	7.137		0.0			
417 to 461	137 128		31.89	2.067		0.0	10.637	0.0159	0.169		Vel = 3.05	
			47.10	2	T	7.137	8.000	100	8.290			
						0.0	7.137		3.898			
			78.99	2.067		0.0	15.137	0.0851	1.288		Vel = 7.55	
461			0.0 78.99						13.476		K Factor = 21.52	
420 to 421	130 130	5.60	17.94	2		0.0	7.000	100	10.258			
						0.0	0.0		0.0			
421 to 422	130 130	5.60	17.94	2.067		0.0	7.000	0.0056	0.039		Vel = 1.72	
						0.0	0.0		0.0			
421 to 422	130 130	5.60	17.97	2	E	3.568	7.500	100	10.297			
						0.0	3.568		0.0			
422 to 423	130 130	5.60	35.91	2.067		0.0	11.068	0.0198	0.219		Vel = 3.43	
						0.0	0.0		0.0			
422 to 423	130 130	5.60	18.16	2		0.0	8.000	100	10.516			
						0.0	0.0		0.0			
423 to 424	130 130	5.60	54.07	2.067		0.0	8.000	0.0421	0.337		Vel = 5.17	
						0.0	0.0		0.0			
423 to 424	130 130	5.60	18.44	2		0.0	6.000	100	10.853			
						0.0	0.0		0.0			
424 to 462	130 128	5.60	72.51	2.067		0.0	6.000	0.0727	0.436		Vel = 6.93	
						0.0	0.0		0.0			
424 to 462	130 128	5.60	18.82	2	E T	3.568	4.000	100	11.289			
						7.137	10.705		0.866			
			91.33	2.067		0.0	14.705	0.1113	1.637		Vel = 8.73	
462			0.0 91.33						13.792		K Factor = 24.59	
425 to 427	138 138	5.60	15.53	1		0.0	4.000	100	7.688			
						0.0	0.0		0.0			
			15.53	1.049		0.0	4.000	0.1142	0.457		Vel = 5.77	
427			0.0 15.53						8.145		K Factor = 5.44	
426 to 427	138 138	5.42	14.89	1	T	3.568	2.000	100	7.557		K = K @ EQ01	
						0.0	3.568		0.0			
			14.89	1.049		0.0	5.568	0.1056	0.588		Vel = 5.53	

Final Calculations - Hazen-Williams

EASTERN FIRE PROTECTION
UNE ALUMNI HALL RENOVATIONS

Page 8
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
427 to 429	138 138		15.53 30.42	1.25 1.38	T	4.282 0.0 0.0	2.000 4.282 6.282	100 0.1043	8.145 0.0 0.655		Vel = 6.53
429			0.0 30.42						8.800		K Factor = 10.25
428 to 429	138 138	5.60	15.75 15.75	1 1.049	T	3.568 0.0	4.000 3.568 7.568	100 0.1173	7.912 0.0 0.888		Vel = 5.85
429 to 463	138 128		30.42 46.17	2 2.067	E T	3.568 7.137 0.0	10.500 10.705 21.205	100 0.0315	8.800 4.331 0.668		Vel = 4.41
463			0.0 46.17						13.799		K Factor = 12.43
430 to 431	130 130	5.60	18.08 18.08	2 2.067		0.0 0.0 0.0	7.000 0.0 7.000	100 0.0056	10.424 0.0 0.039		Vel = 1.73
431 to 432	130 130	5.60	18.11 36.19	2 2.067	E	3.568 0.0	7.000 3.568 10.568	100 0.0201	10.463 0.0 0.212		Vel = 3.46
432 to 433	130 130	5.60	18.30 54.49	2 2.067		0.0 0.0 0.0	7.000 0.0 7.000	100 0.0429	10.675 0.0 0.300		Vel = 5.21
433 to 434	130 130	5.60	18.55 73.04	2 2.067		0.0 0.0 0.0	6.000 0.0 6.000	100 0.0737	10.975 0.0 0.442		Vel = 6.98
434 to 465	130 128	5.60	18.92 91.96	2 2.067	E T	3.568 7.137 0.0	4.000 10.705 14.705	100 0.1128	11.417 0.866 1.658		Vel = 8.79
465			0.0 91.96						13.941		K Factor = 24.63
435 to 437	138 138	5.60	15.70 15.7	1 1.049		0.0 0.0 0.0	3.500 0.0 3.500	100 0.1166	7.863 0.0 0.408		Vel = 5.83
437			0.0 15.70						8.271		K Factor = 5.46
436 to 437	138 138	5.42	15.01 15.01	1 1.049	T	3.568 0.0	2.000 3.568 5.568	100 0.1072	7.674 0.0 0.597		K = K @ EQ01 Vel = 5.57
437 to 439	138 138		15.70 30.71	1.25 1.38	T	4.282 0.0 0.0	2.000 4.282 6.282	100 0.1060	8.271 0.0 0.666		Vel = 6.59
439			0.0 30.71						8.937		K Factor = 10.27
438 to 439	138 138	5.60	15.88 15.88	1 1.049	T	3.568 0.0	4.000 3.568 7.568	100 0.1189	8.037 0.0 0.900		Vel = 5.90

Final Calculations - Hazen-Williams

EASTERN FIRE PROTECTION
UNE ALUMNI HALL RENOVATIONS

Page 9
Date


Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Fng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
439 to 466	138 128		30.71 46.59	2 2.067	E T 3.568 7.137 0.0	10.500 10.705 21.205	100 0.0321	8.937 4.331 0.680		Vel = 4.45	
466			0.0 46.59					13.948		K Factor = 12.47	
460 to 461	128 128		170.59 170.59	4 4.26		12.250 0.0 12.250	100 0.0104	13.348 0.0 0.128		Vel = 3.84	
461 to 464	128 128		78.99 249.58	4 4.26	T 18.795 0.0 0.0	3.500 18.795 22.295	100 0.0211	13.476 0.0 0.471		Vel = 5.62	
464			0.0 249.58					13.947		K Factor = 66.83	
462 to 463	128 128		91.33 91.33	4 4.26		2.000 0.0 2.000	100 0.0035	13.792 0.0 0.007		Vel = 2.06	
463 to 464	128 128		46.17 137.5	4 4.26	I 6.578 0.0 0.0	14.500 6.578 21.078	100 0.0070	13.799 0.0 0.148		Vel = 3.10	
464 to 467	128 128		249.58 387.08	4 4.26		3.500 0.0 3.500	100 0.0474	13.947 0.0 0.166		Vel = 8.71	
467			0.0 387.08					14.113		K Factor = 103.04	
465 to 466	128 128		91.96 91.96	4 4.26		2.000 0.0 2.000	100 0.0035	13.941 0.0 0.007		Vel = 2.07	
466 to 467	128 128		46.59 138.55	4 4.26	T 18.795 0.0 0.0	4.500 18.795 23.295	100 0.0071	13.948 0.0 0.165		Vel = 3.12	
467 to 475	128 130		387.08 525.63	4 4.26	3I 19.734 0.0 0.0	11.500 19.735 31.235	100 0.0838	14.113 -0.866 2.617		Vel = 11.83	
475 to 175	130 112		0.0 525.63	4 4.26		14.000 0.0 14.000	100 0.0838	15.864 7.796 1.173		Vel = 11.83	
175 to 075	112 96.500		0.0 525.63	4 4.26	2I 13.156 T 18.795 0.0	15.500 31.952 47.452	100 0.0838	24.833 6.713 3.976		Vel = 11.83	
075 to DPV	96.500 95		0.0 525.63	6 6.357	2I 17.947 0.0	19.000 17.947 36.947	100 0.0119	35.522 0.650 0.440		Vel = 5.31	
DPV to BOR1	95 93		0.0 525.63	6 6.357	Dge B T 27.661 12.573 37.72	3.000 77.954 80.954	120 0.0085	36.612 0.866 0.689		Vel = 5.31	

Final Calculations - Hazen-Williams

EASTERN FIRE PROTECTION
UNE ALUMNI HALL RENOVATIONS

Page 10
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
BOR1 to BFP	93 92		0.0 525.63	6 6.357	3I 37.72 0.0	6.000 37.720	120 0.0085	38.167 0.433			
BFP to BASE	92 92		0.0 525.63	6 6.357	2I Zma 0.0 0.0	25.147 15.000 25.147 40.147	120 0.0085	38.973 3.136 0.341		** Fixed Loss = 3.136	
BASE to UG1	92 95		0.0 525.63	6 6.16	E T G 4.304	20.084 25.000 43.037 92.425	140 0.0075	42.450 -1.299 0.689			Vel = 5.66
UG1 to TEST	95 95	H100	100.00 625.63	6 6.16	2T 2G 8.607	86.075 450.000 94.682	140 0.0103	41.840 0.0 5.609			Vel = 6.74
TEST			0.0 625.63					47.449			K Factor = 90.82



... **Fire Protection by Computer Design**

EASTERN FIRE PROTECTION
AUBURN, ME
207-784-1507

Job Name : UNE ALUMNI HALL RENOVATIONS
Drawing : 2 OF 2
Location : PORTLAND, MAINE
Remote Area : ATTIC NEW
Contract : AU-5342-15
Data File : 5342 UNE ALUMNI HALL ATTIC NEW.WXF

HYDRAULIC CALCULATIONS
for

Project name: UNE ALUMNI HALL RENOVATIONS
Location: PORTLAND, MAINE
Drawing no: 2 OF 2
Date: 11-12-15

Design

Remote area number: ATTIC NEW
Remote area location: ATTIC NEW
Occupancy classification: LIGHT HAZARD
Density: .1 - Gpm/SqFt
Area of application: 1275 - SqFt
Coverage per sprinkler: 120 - SqFt
Type of sprinklers calculated: RELIABLE FIFR K5.6 UPRIGHT
No. of sprinklers calculated: 13
In-rack demand: - GPM
Hose streams: 100 - GPM
Total water required (including hose streams): 331.524 - GPM @ 51.199 - Psi
Type of system: WET
Volume of dry or preaction system: N/A - Gal

Water supply information

Date: 06-06-12
Location: SEE PLOT PLAN
Source: PORTLAND WATER DISTRICT

Name of contractor: EASTERN FIRE PROTECTION
Address: AUBURN, ME
Phone number: 207-784-1507
Name of designer: GRD
Authority having jurisdiction: MAINE STATE FIRE MARSHAL
Notes: (Include peaking information or gridded systems here.)

Water Supply Curve C


EASTERN FIRE PROTECTION
 UNE ALUMNI HALL RENOVATIONS

City Water Supply:

C1 - Static Pressure : 60
 C2 - Residual Pressure: 54
 C2 - Residual Flow : 1034

Demand:

D1 - Elevation : 12.560
 D2 - System Flow : 231.524
 D2 - System Pressure : 51.199
 Hose (Demand) : 100
 D3 - System Demand : 331.524
 Safety Margin : 8.070



Fittings Used Summary

EASTERN FIRE PROTECTION
UNE ALUMNI HALL RENOVATIONS

Fitting Legend Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24	
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0	
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																				
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	
I	90' Grnd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40	
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65						
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	
Zma	Maxim M200 Horz Butt	Fitting generates a Fixed Loss Based on Flow																				

Units Summary

- Diameter Units Inches
- Length Units Feet
- Flow Units US Gallons per Minute
- Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	60.0	54	1034.0	59.268	331.52	51.199

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
300	116.5	5.6	9.85	17.58	
301	116.5	5.6	9.95	17.67	
302	116.5	5.6	10.32	17.99	
303	116.5	5.6	11.11	18.67	
304	116.5	5.6	12.73	19.98	
305	116.5	5.6	12.85	20.08	
354	0.0		63.92		
306	124.0	5.6	7.0	14.82	
307	124.0	5.6	7.07	14.89	
308	124.0	5.6	7.34	15.17	
309	124.0	5.6	7.92	15.76	
310	124.0	5.6	9.09	16.89	
311	124.0	5.6	9.19	16.98	
352	124.0		9.63		
312	116.5	5.6	20.03	25.06	
350	116.5		20.36		
351	114.0		21.7		
355	114.0		18.71		
353	114.0		19.16		
356	114.0		21.75		
357	114.0		22.86		
174	112.0		24.13		
175	96.5		35.38		
076	96.5		36.13		
TOR2	96.5		39.12		
BOR2	93.0		44.62		
BFP	92.0		45.13		
BASE	92.0		50.61		
UG1	95.0		49.47	100.0	
TEST	95.0		51.2		

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Fng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
300 to 301	116.500 116.500	5.60	17.58	1.5		0.0	8.000	120	9.851			
						0.0	0.0		0.0			
			17.58	1.61		0.0	8.000	0.0127	0.102	Vel =	2.77	
301 to 302	116.500 116.500	5.60	17.66	1.5		0.0	8.000	120	9.953			
						0.0	0.0		0.0			
			35.24	1.61		0.0	8.000	0.0460	0.368	Vel =	5.55	
302 to 303	116.500 116.500	5.60	17.99	1.5		0.0	8.000	120	10.321			
						0.0	0.0		0.0			
			53.23	1.61		0.0	8.000	0.0989	0.791	Vel =	8.39	
303 to 354	116.500 0	5.60	18.67	1.5	T	8.0	5.625	120	11.112			
						0.0	8.000		50.456			
			71.9	1.61		0.0	13.625	0.1723	2.348	Vel =	11.33	
354			0.0									
			71.90						63.916	K Factor =	8.99	
304 to 305	116.500 116.500	5.60	19.98	1.5		0.0	8.000	120	12.725			
						0.0	0.0		0.0			
			19.98	1.61		0.0	8.000	0.0161	0.129	Vel =	3.15	
305 to 354	116.500 0	5.60	20.07	1.5	T	8.0	2.375	120	12.854			
						0.0	8.000		50.456			
			40.05	1.61		0.0	10.375	0.0584	0.606	Vel =	6.31	
354 to 355	0 114		71.91	1.5	T	8.0	2.667	120	63.916			
						0.0	8.000		-49.373			
			111.96	1.61		0.0	10.667	0.3909	4.170	Vel =	17.64	
355			0.0									
			111.96						18.713	K Factor =	25.88	
306 to 307	124 124	5.60	14.82	1.5		0.0	8.000	120	7.000			
						0.0	0.0		0.0			
			14.82	1.61		0.0	8.000	0.0092	0.074	Vel =	2.34	
307 to 308	124 124	5.60	14.89	1.5		0.0	8.000	120	7.074			
						0.0	0.0		0.0			
			29.71	1.61		0.0	8.000	0.0336	0.269	Vel =	4.68	
308 to 309	124 124	5.60	15.18	1.5		0.0	8.000	120	7.343			
						0.0	0.0		0.0			
			44.89	1.61		0.0	8.000	0.0721	0.577	Vel =	7.07	
309 to 352	124 124	5.60	15.75	1.5	T	8.0	5.625	120	7.920			
						0.0	8.000		0.0			
			60.64	1.61		0.0	13.625	0.1257	1.713	Vel =	9.56	
352			0.0									
			60.64						9.633	K Factor =	19.54	
310 to 311	124 124	5.60	16.89	1.5		0.0	8.000	120	9.095			
						0.0	0.0		0.0			
			16.89	1.61		0.0	8.000	0.0118	0.094	Vel =	2.66	
311 to 352	124 124	5.60	16.97	1.5	T	8.0	2.375	120	9.189			
						0.0	8.000		0.0			
			33.86	1.61		0.0	10.375	0.0428	0.444	Vel =	5.34	

Final Calculations - Hazen-Williams

EASTERN FIRE PROTECTION
UNE ALUMNI HALL RENOVATIONS

Page 6
Date


Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Fng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
352 to 353	124 114		60.65 94.51	1.5 1.61	T	8.0 0.0	10.170 8.000	120	9.633 4.331			
			0.0			0.0	18.170	0.2858	5.193		Vel = 14.89	
353			94.51						19.157		K Factor = 21.59	
312 to 350	116.500 116.500	5.60	25.06 25.06	1.5 1.61	T	8.0 0.0	5.625 8.000	120	20.026 0.0			
			0.0			0.0	13.625	0.0245	0.334		Vel = 3.95	
350 to 351	116.500 114		0.0 25.06	1.5 1.61	T	8.0 0.0	2.667 8.000	120	20.360 1.083			
			0.0			0.0	10.667	0.0245	0.261		Vel = 3.95	
351			25.06						21.704		K Factor = 5.38	
351 to 356	114 114		25.06 25.06	2.5	T	16.474 0.0	4.500 16.474	120	21.704 0.0			
			0.0			0.0	20.974	0.0022	0.047		Vel = 1.47	
356			25.06						21.751		K Factor = 5.37	
355 to 353	114 114		111.96 111.96	2.5		0.0 0.0	12.500 0.0	120	18.713 0.0			
			0.0			0.0	12.500	0.0355	0.444		Vel = 6.59	
353 to 356	114 114		94.50 206.46	2.5	T	16.474 0.0	7.080 16.474	120	19.157 0.0			
			0.0			0.0	23.554	0.1101	2.594		Vel = 12.15	
356 to 357	114 114		25.06 231.52	3	I	6.72 0.0	16.250 6.720	120	21.751 0.0			
			0.0			0.0	22.970	0.0483	1.109		Vel = 8.90	
357 to 174	114 112		0.0 231.52	3	I	6.72 0.0	1.667 6.720	120	22.860 0.866			
			0.0			0.0	8.387	0.0483	0.405		Vel = 8.90	
174 to 175	112 96.500		0.0 231.52	3	4I T	26.879 20.159	47.000 47.038	120	24.131 6.713			
			0.0			0.0	94.038	0.0483	4.540		Vel = 8.90	
175 to 076	96.500 96.500		0.0 231.52	3		0.0 0.0	15.500 0.0	120	35.384 0.0			
			0.0			0.0	15.500	0.0483	0.749		Vel = 8.90	
076 to TOR2	96.500 96.500		0.0 231.52	3	3I T	20.159 20.159	21.500 40.318	120	36.133 0.0			
			0.0			0.0	61.818	0.0483	2.985		Vel = 8.90	
TOR2 to BOR2	96.500 93		0.0 231.52	4	S T	28.968 15.8	4.000 71.102	120	39.118 4.516		** Fixed Loss = 3	
			0.0			0.0	75.102	0.0131	0.985		Vel = 5.21	
BOR2 to BFP	93 92		0.0 231.52	6	3I	37.72 0.0	4.000 37.720	120	44.619 0.433			
			0.0			0.0	41.720	0.0019	0.078		Vel = 2.34	

Final Calculations - Hazen-Williams

EASTERN FIRE PROTECTION
UNE ALUMNI HALL RENOVATIONS

Page 7
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	***** Notes *****
BFP to BASE	92 92		0.0 231.52	6 6.357	2I Zma	25.147 0.0	15.000 25.147	120	45.130 5.410	** Fixed Loss = 5.41 Vel = 2.34
BASE to UG1	92 95		0.0 231.52	6 6.16	E T G	20.084 43.037 4.304	25.000 67.425 92.425	140	50.614 -1.299 0.151	Vel = 2.49
UG1 to TEST	95 95	H100	100.00 331.52	6 6.16	2T 2G	86.075 8.607 0.0	450.000 94.682 544.682	140	49.466 0.0 1.733	Vel = 3.57
TEST			0.0 331.52						51.199	K Factor = 46.33



... Fire Protection by Computer Design

EASTERN FIRE PROTECTION
AUBURN, ME
207-784-1507

Job Name : UNE ALUMNI HALL RENOVATIONS
Drawing : 2 OF 2
Location : PORTLAND, MAINE
Remote Area : 2ND FLOOR
Contract : AU-5342-15
Data File : 5342 UNE ALUMNI SECOND FLOOR WET SYSTEM.WXF

HYDRAULIC CALCULATIONS
for

Project name: UNE ALUMNI HALL RENOVATIONS
Location: PORTLAND, MAINE
Drawing no: 2 OF 2
Date: 11-12-15

Design

Remote area number: 2ND FLOOR
Remote area location: 2ND FLOOR
Occupancy classification: LIGHT HAZARD
Density: .10 - Gpm/SqFt
Area of application: 910 - SqFt
Coverage per sprinkler: 196 - SqFt
Type of sprinklers calculated: RELIABLE F1FR K5.6 UPRIGHT
No. of sprinklers calculated: 8
In-rack demand: - GPM
Hose streams: 100 - GPM
Total water required (including hose streams): 273.295 - GPM @ 48.807 - Psi
Type of system: WET
Volume of dry or preaction system: - Gal

Water supply information

Date: 06-06-12
Location: SEE PLOT PLAN DWG 1 OF 2
Source: PORTLAND WATER DISTRICT

Name of contractor: EASTERN FIRE PROTECTION
Address: AUBURN, ME
Phone number: 207-784-1507
Name of designer: GRD
Authority having jurisdiction: MAINE STATE FIRE MARSHAL
Notes: (Include peaking information or gridded systems here.)

Water Supply Curve C


EASTERN FIRE PROTECTION
 UNE ALUMNI HALL RENOVATIONS

City Water Supply:

C1 - Static Pressure : 60
 C2 - Residual Pressure: 54
 C2 - Residual Flow : 1034

Demand:

D1 - Elevation : 12.560
 D2 - System Flow : 173.295
 D2 - System Pressure : 48.807
 Hose (Demand) : 100
 D3 - System Demand : 273.295
 Safety Margin : 10.682



Fittings Used Summary

EASTERN FIRE PROTECTION
UNE ALUMNI HALL RENOVATIONS

Fitting Legend Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24	
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0	
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	
Fsp	Flow Switch Poller VSR	Fitting generates a Fixed Loss Based on Flow																				
G	NFPA 13 Gate Valve	0	0	0	0	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40	
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65						
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	
Zca	Coil C200 Horz Butt	Fitting generates a Fixed Loss Based on Flow																				

Units Summary

- Diameter Units Inches
- Length Units Feet
- Flow Units US Gallons per Minute
- Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	60.0	54	1034.0	59.488	273.3	48.807

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
DP01	0.0	5.6	12.25	19.6	
DP02	0.0	5.6	12.25	19.6	
200	124.0	5.44	17.45	22.71	K=K @ EQ01
201	124.0	5.52	16.52	22.42	K=K @ EQ02
202	124.0		17.8		
203	124.0	5.44	17.93	23.02	K=K @ EQ01
204	124.0	5.44	19.59	24.06	K=K @ EQ01
207	124.0	5.44	13.19	19.74	K=K @ EQ01
208	124.0	5.44	13.59	20.04	K=K @ EQ01
209	124.0	5.52	12.63	19.6	K=K @ EQ02
210	124.0		13.71		
211	124.0	5.44	15.95	21.71	K=K @ EQ01
205	124.0		20.06		
212	124.0		20.4		
215	124.0		23.88		
276	124.0		24.39		
076	96.5		37.08		
TOR2	96.5		38.83		
BOR2	93.0		43.92		
BFP	92.0		44.4		
BASE	92.0		48.61		
UG1	95.0		47.39	100.0	
TEST	95.0		48.81		


Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
DP01 to EQ01	0 0	5.60	19.60 19.6	1 1.049	T	5.0 0.0 0.0	1.000 5.000 6.000	120 0.1253	12.250 0.0 0.752		Vel = 7.28	
EQ01			0.0 19.60						13.002		K Factor = 5.44	
DP02 to EQ02	0 0	5.60	19.60 19.6	1 1.049	E	2.0 0.0 0.0	1.000 2.000 3.000	120 0.1253	12.250 0.0 0.376		Vel = 7.28	
EQ02			0.0 19.60						12.626		K Factor = 5.52	
200 to 202	124 124	5.44	22.71 22.71	1.25 1.442		0.0 0.0 0.0	10.000 0.0 10.000	120 0.0349	17.455 0.0 0.349		K = K @ EQ01 Vel = 4.46	
202			0.0 22.71						17.804		K Factor = 5.38	
201 to 202	124 124	5.52	22.42 22.42	1 1.049	T	5.0 0.0 0.0	3.000 5.000 8.000	120 0.1608	16.518 0.0 1.286		K = K @ EQ02 Vel = 8.32	
202 to 203	124 124		22.71 45.13	1.25 1.442		0.0 0.0 0.0	1.000 0.0 1.000	120 0.1250	17.804 0.0 0.125		Vel = 8.87	
203 to 205	124 124	5.44	23.01 68.14	1.25 1.442		0.0 0.0 0.0	8.000 0.0 8.000	120 0.2669	17.929 0.0 2.135		K = K @ EQ01 Vel = 13.39	
205			0.0 68.14						20.064		K Factor = 15.21	
204 to 205	124 124	5.44	24.06 24.06	1.25 1.38	T	6.0 0.0 0.0	3.750 6.000 9.750	120 0.0482	19.594 0.0 0.470		K = K @ EQ01 Vel = 5.16	
205			0.0 24.06						20.064		K Factor = 5.37	
207 to 208	124 124	5.44	19.74 19.74	1.25 1.38		0.0 0.0 0.0	12.000 0.0 12.000	120 0.0333	13.190 0.0 0.400		K = K @ EQ01 Vel = 4.23	
208 to 210	124 124	5.44	20.04 39.78	1.25 1.38		0.0 0.0 0.0	1.000 0.0 1.000	120 0.1220	13.590 0.0 0.122		K = K @ EQ01 Vel = 8.53	
210			0.0 39.78						13.712		K Factor = 10.74	
209 to 210	124 124	5.52	19.60 19.6	1 1.049	T	5.0 0.0 0.0	3.667 5.000 8.667	120 0.1253	12.626 0.0 1.086		K = K @ EQ02 Vel = 7.28	
210 to 211	124 124		39.78 59.38	1.25 1.38		0.0 0.0 0.0	8.750 0.0 8.750	120 0.2563	13.712 0.0 2.243		Vel = 12.74	

Final Calculations - Hazen-Williams

EASTERN FIRE PROTECTION
UNE ALUMNI HALL RENOVATIONS

Page 6
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
211 to 212	124 124	5.44	21.71 81.09	1.25 1.38	T 0.0	6.0 0.0	3.750 6.000	120 0.0	15.955 0.0	K = K @ EQ01	
212			0.0 81.09			0.0	9.750	0.4561	4.447	Vel = 17.39	
212									20.402	K Factor = 17.95	
205 to 212	124 124		92.20 92.2	2.5 2.635	0.0 0.0	0.0 0.0	13.625 13.625	120 0.0248	20.064 0.0 0.338	Vel = 5.42	
212 to 215	124 124		81.10 173.3	2.5 2.635	T 0.0	16.474 0.0	27.250 16.474	120 0.0796	20.402 0.0 3.482	Vel = 10.20	
215 to 276	124 124		0.0 173.3	3 3.26	I 0.0	6.72 0.0	11.250 6.720	120 0.0283	23.884 0.0 0.508	Vel = 6.66	
276 to 076	124 96.500		0.0 173.3	3 3.26	0.0 0.0	0.0 0.0	27.667 27.667	120 0.0283	24.392 11.910 0.782	Vel = 6.66	
076 to TOR2	96.500 96.500		0.0 173.3	3 3.26	3I T 0.0	20.159 20.159 0.0	21.500 40.318 61.818	120 0.0282	37.084 0.0 1.746	Vel = 6.66	
TOR2 to BOR2	96.500 93		0.0 173.3	4 4.26	S B T Fsp 0.0	28.968 15.8 26.334 0.0	4.000 71.102 75.102	120 0.0077	38.830 4.516 0.577	** Fixed Loss = 3 Vel = 3.90	
BOR2 to BFP	93 92		0.0 173.3	6 6.357	3I 0.0	37.72 0.0	4.000 37.720	120 0.0011	43.923 0.433 0.045	Vel = 1.75	
BFP to BASE	92 92		0.0 173.3	6 6.357	2I Zca 0.0	25.147 0.0	15.000 25.147	120 0.0011	44.401 4.160 0.044	** Fixed Loss = 4.16 Vel = 1.75	
BASE to UG1	92 95		0.0 173.3	6 6.16	E T G	20.084 43.037 4.304	25.000 67.425 92.425	140 0.0010	48.605 -1.299 0.088	Vel = 1.87	
UG1 to TEST	95 95	H100	100.00 273.3	6 6.16	2T 2G 0.0	86.075 8.607 0.0	540.000 94.682 634.682	140 0.0022	47.394 0.0 1.413	Vel = 2.94	
TEST			0.0 273.30						48.807	K Factor = 39.12	



... **Fire Protection by Computer Design**

EASTERN FIRE PROTECTION
AUBURN, ME
207-784-1507

Job Name : UNE ALUMNI HALL RENOVATIONS
Drawing : 1 OF 2
Location : PORTLAND, MAINE
Remote Area : LOWER LEVEL
Contract : AU-5342-15
Data File : 5342 UNE ALUMNI HALL LOWER LEVEL EXISTING.WXF

HYDRAULIC CALCULATIONS
for

Project name: UNE ALUMNI HALL RENOVATIONS
Location: PORTLAND, MAINE
Drawing no: 1 OF 2
Date: 11-12-15

Design

Remote area number: LOWER LEVEL
Remote area location: LOWER LEVEL
Occupancy classification: ORDINARY HAZARD GROUP I
Density: .15 - Gpm/SqFt
Area of application: 1090 - SqFt
Coverage per sprinkler: 120 - SqFt
Type of sprinklers calculated: RELIABLE FIFR K5.6 UPRIGHT
No. of sprinklers calculated: 14
In-rack demand: - GPM
Hose streams: 250 - GPM
Total water required (including hose streams): 517.951 - GPM @ 35.186 - Psi
Type of system: WET
Volume of dry or preaction system: N/A - Gal

Water supply information

Date: 06-06-12
Location: SEE PLOT PLAN
Source: PORTLAND WATER DISTRICT

Name of contractor: EASTERN FIRE PROTECTION
Address: AUBURN, ME
Phone number: 207-784-1507
Name of designer: GRD
Authority having jurisdiction: MAINE STATE FIRE MARSHAL
Notes: (Include peaking information or gridded systems here.)

Water Supply Curve C


EASTERN FIRE PROTECTION
 UNE ALUMNI HALL RENOVATIONS

City Water Supply:

C1 - Static Pressure : 60
 C2 - Residual Pressure: 54
 C2 - Residual Flow : 1034

Demand:

D1 - Elevation : 1.299
 D2 - System Flow : 267.951
 D2 - System Pressure : 35.186
 Hose (Demand) : 250
 D3 - System Demand : 517.951
 Safety Margin : 23.144



Fittings Used Summary

EASTERN FIRE PROTECTION UNE ALUMNI HALL RENOVATIONS

Fitting Legend Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24	
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0	
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																				
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40	
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65						
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	
Zma	Maxim M200 Horz Butt	Fitting generates a Fixed Loss Based on Flow																				

Units Summary

- Diameter Units Inches
- Length Units Feet
- Flow Units US Gallons per Minute
- Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	60.0	54	1034.0	58.33	517.95	35.186

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
1	98.0	5.6	10.8	18.4	
2	98.0	5.6	10.58	18.21	
3	98.0	5.6	11.51	18.99	
4	98.0		12.53		
6	98.0	5.6	11.64	19.1	
7	98.0	5.6	12.41	19.73	
8	98.0		13.49		
10	98.0	5.6	10.94	18.52	
11	98.0	5.6	10.33	18.0	
12	98.0	5.6	11.67	19.13	
13	98.0		12.69		
15	98.0	5.6	10.81	18.41	
16	98.0	5.6	11.7	19.16	
17	98.0	5.6	10.92	18.5	
18	98.0	5.6	11.93	19.35	
20	98.0		12.94		
21	98.0	5.6	13.74	20.76	
22	98.0	5.6	14.99	21.68	
50	96.0		15.21		
51	96.0		15.29		
52	96.0		15.38		
53	96.0		16.99		
54	96.0		17.64		
55	96.0		17.78		
TOR2	96.5		20.87		
BOR2	93.0		26.68		
BFP	92.0		27.21		
BASE	92.0		32.33		
UG1	95.0		31.23	250.0	
TEST	95.0		35.19		

EASTERN FIRE PROTECTION
UNE ALUMNI HALL RENOVATIONS

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
1 to 4	98 98	5.60	18.40 18.4	1 1.049	T	5.0 0.0	10.500 5.000	120	10.801 0.0			
			0.0			0.0	15.500	0.1115	1.729	Vel =	6.83	
4			18.40						12.530	K Factor =	5.20	
2 to 3	98 98	5.60	18.21 18.21	1 1.049	2E	4.0 0.0	4.500 4.000	120	10.575 0.0			
						0.0	8.500	0.1094	0.930	Vel =	6.76	
3 to 4	98 98	5.60	19.00 37.21	1.25 1.38	T	6.0 0.0	3.500 9.500	120	11.505 0.0			
						0.0	2.000	0.1079	1.025	Vel =	7.98	
4 to 50	98 96		18.40 55.61	1.25 1.38	T	6.0 0.0	2.000 8.000	120	12.530 0.866			
			0.0			0.0	8.000	0.2270	1.816	Vel =	11.93	
50			55.61						15.212	K Factor =	14.26	
6 to 8	98 98	5.60	19.10 19.1	1 1.049	T	5.0 0.0	10.500 5.000	120	11.638 0.0			
						0.0	15.500	0.1195	1.853	Vel =	7.09	
8			0.0 19.10						13.491	K Factor =	5.20	
7 to 8	98 98	5.60	19.73 19.73	1 1.049	T	5.0 0.0	3.500 5.000	120	12.413 0.0			
						0.0	8.500	0.1268	1.078	Vel =	7.32	
8 to 51	98 96		19.10 38.83	1.25 1.38	T	6.0 0.0	2.000 8.000	120	13.491 0.866			
			0.0			0.0	8.000	0.1169	0.935	Vel =	8.33	
51			38.83						15.292	K Factor =	9.93	
10 to 13	98 98	5.60	18.52 18.52	1 1.049	T	5.0 0.0	10.500 5.000	120	10.941 0.0			
						0.0	15.500	0.1130	1.751	Vel =	6.88	
13			0.0 18.52						12.692	K Factor =	5.20	
11 to 12	98 98	5.60	18.00 18.0	1 1.049	3E	6.0 0.0	6.500 6.000	120	10.332 0.0			
						0.0	12.500	0.1070	1.338	Vel =	6.68	
12 to 13	98 98	5.60	19.13 37.13	1.25 1.38	T	6.0 0.0	3.500 9.500	120	11.670 0.0			
						0.0	2.000	0.1076	1.022	Vel =	7.96	
13 to 52	98 96		18.52 55.65	1.25 1.38	T	6.0 0.0	2.000 8.000	120	12.692 0.866			
			0.0			0.0	8.000	0.2272	1.818	Vel =	11.94	
52			55.65						15.376	K Factor =	14.19	

Final Calculations - Hazen-Williams

EASTERN FIRE PROTECTION
UNE ALUMNI HALL RENOVATIONS

Page 6
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
15 to 16	98 98	5.60	18.41	1		0.0	8.000	120	10.807			
						0.0	0.0		0.0			
			18.41	1.049		0.0	8.000	0.1116	0.893	Vel =	6.83	
16 to 20	98 98	5.60	19.15	1.25	T	6.0	5.250	120	11.700			
						0.0	6.000		0.0			
			37.56	1.38		0.0	11.250	0.1099	1.236	Vel =	8.06	
			0.0									
20			37.56						12.936	K Factor =	10.44	
17 to 18	98 98	5.60	18.50	1		0.0	9.000	120	10.919			
						0.0	0.0		0.0			
			18.5	1.049		0.0	9.000	0.1128	1.015	Vel =	6.87	
18 to 20	98 98	5.60	19.35	1.25	T	6.0	3.000	120	11.934			
						0.0	6.000		0.0			
			37.85	1.38		0.0	9.000	0.1113	1.002	Vel =	8.12	
20 to 53	98 96		37.57	1.25	T	6.0	2.000	120	12.936			
						0.0	6.000		0.866			
			75.42	1.38		0.0	8.000	0.3989	3.191	Vel =	16.18	
			0.0									
53			75.42						16.993	K Factor =	18.30	
21 to 22	98 98	5.60	20.76	1		0.0	9.000	120	13.737			
						0.0	0.0		0.0			
			20.76	1.049		0.0	9.000	0.1393	1.254	Vel =	7.71	
22 to 55	98 96	5.60	21.68	1.25	E T	3.0	5.000	120	14.991			
						6.0	9.000		0.866			
			42.44	1.38		0.0	14.000	0.1377	1.928	Vel =	9.10	
			0.0									
55			42.44						17.785	K Factor =	10.06	
50 to 51	96 96		55.61	2.5		0.0	8.170	120	15.212			
						0.0	0.0		0.0			
			55.61	2.635		0.0	8.170	0.0098	0.080	Vel =	3.27	
51 to 52	96 96		38.83	2.5		0.0	3.250	120	15.292			
						0.0	0.0		0.0			
			94.44	2.635		0.0	3.250	0.0258	0.084	Vel =	5.56	
52 to 53	96 96		55.66	2.5	2l	16.474	10.000	120	15.376			
						0.0	16.474		0.0			
			150.1	2.635		0.0	26.474	0.0611	1.617	Vel =	8.83	
53 to 54	96 96		75.41	2.5		0.0	5.000	120	16.993			
						0.0	0.0		0.0			
			225.51	2.635		0.0	5.000	0.1296	0.648	Vel =	13.27	
54 to 55	96 96		0.0	3		0.0	3.125	120	17.641			
						0.0	0.0		0.0			
			225.51	3.26		0.0	3.125	0.0461	0.144	Vel =	8.67	
55 to TOR2	96 96.500		42.44	3	3l	20.159	32.000	120	17.785			
						0.0	20.159		-0.217			
			267.95	3.26		0.0	52.159	0.0633	3.300	Vel =	10.30	

Final Calculations - Hazen-Williams

EASTERN FIRE PROTECTION
UNE ALUMNI HALL RENOVATIONS

Page 7
Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
TOR2 to BOR2	96.500 93		0.0 267.95	4 4.26	S B T	28.968 15.8 26.334	4.000 71.102 75.102	120 0.0172	20.868 4.516 1.291		** Fixed Loss = 3 Vel = 6.03	
BOR2 to BFP	93 92		0.0 267.95	6 6.357	3I	37.72 0.0 0.0	4.000 37.720 41.720	120 0.0024	26.675 0.433 0.102		Vel = 2.71	
BFP to BASE	92 92		0.0 267.95	6 6.357	2I Zma	25.147 0.0 0.0	15.000 25.147 40.147	120 0.0024	27.210 5.024 0.098		** Fixed Loss = 5.024 Vel = 2.71	
BASE to UG1	92 95		0.0 267.95	6 6.16	E T G	20.084 43.037 4.304	25.000 67.425 92.425	140 0.0021	32.332 -1.299 0.198		Vel = 2.88	
UG1 to TEST	95 95	H250	250.00 517.95	6 6.16	2T 2G	86.075 8.607 0.0	450.000 94.682 544.682	140 0.0073	31.231 0.0 3.955		Vel = 5.58	
TEST			0.0 517.95						35.186		K Factor = 87.32	