

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

UNIVERSITY OF NEW ENGLAND

Located at

714 STEVENS AVE

PERMIT ID: 2015-02889

ISSUE DATE: 12/28/2015

CBL: 145 A003001

has permission to **For the installation of a Water-Based Fire Suppression System - new NFPA 13 wet/dry fire sprinkler system to limit of work for the "University of New England (UNE)" - Alumni Hall.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2015-02889	Date Applied For: 12/01/2015	CBL: 145 A003001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: College - University of New England (UNE) -Alumni Hall		Proposed Project Description: For the installation of a Water-Based Fire Suppression System - new NFPA 13 wet/dry fire sprinkler system to limit of work for the "University of New England (UNE)" - Alumni Hall.		
Dept: Historic	Status: Approved w/Conditions	Reviewer: Robert Wiener	Approval Date: 12/23/2015	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) Sign and plate for fire department sprinkler connection are to be bronze.				
2) Approved location for fire department sprinkler connection is on north side of building, near front corner. If this location is impossible because of Fire Department requirements, the front corner location would be acceptable.				
Dept: Zoning	Status: Approved w/Conditions	Reviewer: Tammy Munson	Approval Date: 12/01/2015	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) This approves the installation of the system only. It does not certify the legal use of the building.				
Dept: Building Inspecti	Status: Approved	Reviewer: Tammy Munson	Approval Date: 12/01/2015	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
Dept: Engineering DPS	Status: Not Applicable	Reviewer:	Approval Date: 12/02/2015	Ok to Issue: <input type="checkbox"/>
Note:				
Conditions:				
1) This approval is non-applicable to Engineering DPS as it relates to approval for Grease Control Equipment for the Fats, Oil, and Grease Program. If approval is needed for this project by the Engineering Department of Public Services for any other reason than FOG, please contact David Margolis-Pineo at 207-874-8850 or dmp@portlandmaine.gov				
Dept: Fire	Status: Approved w/Conditions	Reviewer: Craig Messinger	Approval Date: 12/14/2015	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) A copy of the State Sprinkler permit with RMS date and signature and the Contractor's Material and Test Certificate for Aboveground Piping (NFPA 13 figure 24.1) shall be provided prior to scheduling of the final inspection.				
2) A sprinkler supervisory system shall be provided in accordance with NFPA 101, Life Safety Code, and NFPA 72, National Fire Alarm and Signaling Code. Sprinkler supervisory systems shall monitor for water flow and sprinkler supervisory signals via an approved fire alarm panel to central station. One smoke detector shall be located over the panel, a manual pull station located at the front door, and an audible water flow alarm provided. A separate fire alarm permit is required from a certified fire alarm company.				
3) The entire sprinkler system shall be maintained in accordance with NFPA 25, Standard for Inspection, Testing and Maintenance of Water-Based Fire Protection Systems, 2008 edition. This applies to the entire building and a letter must be submitted to the Fire Prevention Office, before a final inspection is scheduled. The intent of this requirement is to verify code compliance for the entire building.				
4) Shall meet the requirements of 2009 NFPA 1 Fire Code.				