



March 21, 2016

From: Jim Pickett, NICET IV

To: Tim Biron; RB Allen Co., Inc

Subject: Fire Alarm System Review for Abplanalp Library UNE Portland, ME

I have performed a review of the fire alarm system design drawings for the renovations to Abplanalp Library at UNE Portland on College Ave, Portland Maine. The submittal package included the floor plans, riser diagram, battery calculations, and cut sheets.

I have found that the revision, dated March 18, 2016, of the fire alarm system design to be code compliant and adequately supports the fire detection, alarm, and notification requirements of this facility.

Jim Pickett

NICET Cert IV #96403 2/99

RB Allen Co., Inc