



Portland Fire Department

10/16/2019

UNIVERSITY OF NEW ENGLAND
716 STEVENS AVENUE
PORTLAND, ME 04103
ghogan@une.edu

CERTIFIED MAIL

RE: 716 STEVENS AVE
PORTLAND, ME 04103

145 B014001

Page 1 of 2

**NOTICE OF VIOLATION
AND ORDER TO CORRECT**

To Whom it May Concern,

The City of Portland inspected the above-referenced property on 4/3/2019 and found violations of the City of Portland Code of Ordinances, which are listed on the attached page(s). You are hereby ordered to correct these violations by the dates given on the attached.

A reinspection of your property will take place on 11/15/2019 10:00:00AM .

Please contact the Fire Prevention Bureau at 874-8400 if you have any question about your reinspection. If the violations are not corrected at the time of reinspection, you will be charged a \$150 failed reinspection fee.

If you do not correct the attached violations, then this matter may be referred to the City of Portland Corporation Counsel for legal action, including civil penalties and other legal remedies.

Thank you for keeping the City of Portland safe.

Sincerely,

Captain John Brennan
Fire Prevention Bureau
City of Portland

NON-COMPLIANCE VIOLATION LIST

NAME	CODE DESCRIPTION	COMMENTS	Deadline
NFPA 101-4.5.8, 7.9.3	Emergency lights must be kept in good working order.	Emergency Lights throughout Ginn & McDougall Hall	5/3/2019
NFPA 101-9.1.2; NFPA 70	All electrical equipment must comply with the National Electric Code.	Open Auto Transfer box in Boiler Room of McDougall Hall	5/3/2019