



DRAWING KEYNOTES

- 1. FOR HWS AND HWR PIPING CONTINUATION REFER TO SHEET CS/102.
- 2. RUN PIPING IN BEAM SPACE.
- 3. PROVIDE SUPPORT BRACKETS FOR BOTH LPS AND PC PIPE 5 FEET ABOVE FLOOR LEVEL. PROVIDE PIPE EXPANSION GUIDES 5 FEET FROM TOP OF THE LPS AND PC RISERS. BRACKETS TO PROVIDE SUPPORT BUT TO PERMIT FREEDOM OF MOVEMENT ASSOCIATED WITH THERMAL EXPANSION.
- 4. HWS/HWR DROPS DOWN TO 1ST FLOOR PR-1. SEE MP102.
- 5. TO HEATING COIL HC-1 CONTROL VALVE. LOCATED IN 206 STORAGE ROOM.

DRAWING NOTES

- 1. VERTICAL HYDRONIC PIPING TO RADIANT PANELS AND FIN TUBE TO BE RUN IN WALLS UNLESS OTHERWISE NOTED.

1 SECOND FLOOR MECHANICAL PIPING PART PLAN

MP102 MP103 SCALE: 1/8"=1'-0"

