

FIRE ALARM AND EMERGENCY COMMUNICATION SYSTEM INSPECTION AND TESTING FORM

To be completed by the system inspector or tester at the time of the inspection or test.
It shall be permitted to modify this form as needed to provide a more complete and/or clear record.
Insert N/A in all unused lines.
Attach additional sheets, data, or calculations as necessary to provide a complete record.

Date of this inspection or test: 5/4/17 Time of inspection or test: 10:15

1. PROPERTY INFORMATION

Name of property: Aurora Provisions
Address: 64 Pine Street; Portland, ME 04102
Description of property:
Occupancy type:
Name of property representative:
Address:
Phone: Fax: E-mail:
Authority having jurisdiction over this property: Portland FD
Phone: Fax: E-mail:

2. INSTALLATION, SERVICE, AND TESTING CONTRACTOR INFORMATION

Service and/or testing organization for this equipment: Cunningham Security Systems
Address: 10 Princes Point Road, Yarmouth, ME 04096
Phone: (207) 846-3350 Fax: (207) 846-6080 E-mail: info@cunninghamsecurity.com
Service technician or tester: BRIAN EWINGS
Qualifications of technician or tester: IMSA
A contract for test and inspection in accordance with NFPA standards is in effect as of:
The contract expires: Contract number: Frequency of tests and inspections: Annual
Monitoring organization for this equipment: Centra-Larm Monitoring, Inc.
A contract for test and inspection in accordance with NFPA standards is in effect as of:
Address: 994 Candia Road, Manchester, NH 03109
Phone: 1-800-639-2066 Fax: (603) 668-1117 E-mail: inputting@centragroup.net
Entity to which alarms are retransmitted: Phone:

3. TYPE OF SYSTEM OR SERVICE

- Fire alarm system (nonvoice)
- Fire alarm with in-building fire emergency voice alarm communication system (EVACS)
- Mass notification system (MNS)
- Combination system, with the following components:
 - Fire alarm
 - EVACS
 - MNS
 - Two-way, in-building, emergency communication system
- Other (specify):

3. TYPE OF SYSTEM OR SERVICE (continued)

NFPA 72 edition:

Additional description of system(s):

3.1 Control Unit

Manufacturer: Silent Knight

Model number: ~~5204~~ 5208

3.2 Mass Notification System

This system does not incorporate an MNS

3.2.1 System Type:

In-building MNS—combination

In-building MNS—stand-alone Wide-area MNS Distributed recipient MNS

Other (specify):

3.2.2 System Features:

Combination fire alarm/MNS MNS ACU only Wide-area MNS to regional national alerting interface

Local operating console (LOC) Direct recipient MNS (DRMNS) Wide-area MNS to DRMNS interface

Wide-area MNS to high-power speaker array (HPSA) interface In-building MNS to wide-area MNS interface

Other (specify):

3.3 System Documentation

An owner's manual, a copy of the manufacturer's instructions, a written sequence of operation, and a copy of the record record drawings are stored on site. Location:

3.4 System Software

This system does not have alterable site-specific software.

Software revision number:

Software last updated on:

A copy of the site-specific software is stored on site. Location:

4. SYSTEM POWER

4.1 Control Unit

4.1.1 Primary Power

Input voltage of control panel: 120 VAC

Control panel amps: 2.5

4.1.2 Engine-Driven Generator

This system does not have a generator.

Location of generator:

Location of fuel storage:

Type of fuel:

4.1.3 Uninterruptible Power System

This system does not have UPS.

Equipment powered by a UPS system:

Location of UPS system:

Calculated capacity of UPS batteries to drive the system components connected to it:

In standby mode (hours):

In alarm mode (minutes):

7. TESTING RESULTS (continued)

7.2 Control Unit Power Supplies

Description	Visual Inspection	Functional Test	Comments
120-volt power	<input type="checkbox"/>	<input type="checkbox"/>	<i>BATTERIES GOOD - DATED 3/24/16</i>
Generator or UPS	<input type="checkbox"/>	<input type="checkbox"/>	
Battery condition	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Load voltage	<input type="checkbox"/>	<input type="checkbox"/>	
Discharge test	<input type="checkbox"/>	<input type="checkbox"/>	
Charger test	<input type="checkbox"/>	<input type="checkbox"/>	
Other (specify)	<input type="checkbox"/>	<input type="checkbox"/>	

7.3 In-Building Fire Emergency Voice Alarm Communications Equipment

Description	Visual Inspection	Functional Test	Comments
Control unit	<input type="checkbox"/>	<input checked="" type="checkbox"/>	_____
Lamps/LEDs/LCDs	<input type="checkbox"/>	<input type="checkbox"/>	
Fuses	<input type="checkbox"/>	<input type="checkbox"/>	
Primary power supply	<input type="checkbox"/>	<input type="checkbox"/>	
Secondary power supply	<input type="checkbox"/>	<input type="checkbox"/>	
Trouble signals	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Disconnect switches	<input type="checkbox"/>	<input type="checkbox"/>	
Ground-fault monitoring	<input type="checkbox"/>	<input type="checkbox"/>	
Panel supervision	<input type="checkbox"/>	<input type="checkbox"/>	
System performance	<input type="checkbox"/>	<input type="checkbox"/>	
Sound pressure levels	<input type="checkbox"/>	<input type="checkbox"/>	
Occupied <input type="checkbox"/> Yes <input type="checkbox"/> No			
Ambient dBA			
Alarm dBA (attach report with locations, values, and weather conditions)			
System intelligibility	<input type="checkbox"/>	<input type="checkbox"/>	
<input type="checkbox"/> CSI <input type="checkbox"/> STI (attach report with locations, values, and weather conditions)			
Other (specify)	<input type="checkbox"/>	<input type="checkbox"/>	

7. TESTING RESULTS (continued)

7.4 Notification Appliance Power Extender Panels

Description	Visual Inspection	Functional Test	Comments
Lamps/LEDs/LCDs	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Fuses	<input type="checkbox"/>	<input type="checkbox"/>	
Primary power supply	<input type="checkbox"/>	<input type="checkbox"/>	
Secondary power supply	<input type="checkbox"/>	<input type="checkbox"/>	
Trouble signals	<input type="checkbox"/>	<input type="checkbox"/>	
Ground-fault monitoring	<input type="checkbox"/>	<input type="checkbox"/>	
Panel supervision	<input type="checkbox"/>	<input type="checkbox"/>	
Other (specify)	<input type="checkbox"/>	<input type="checkbox"/>	

7.5 Mass Notification Equipment

Description	Visual Inspection	Functional Test	Comments
Functional test	<input type="checkbox"/>	<input type="checkbox"/>	
Reset/power down test	<input type="checkbox"/>	<input type="checkbox"/>	
Fuses	<input type="checkbox"/>	<input type="checkbox"/>	
Primary power supply	<input type="checkbox"/>	<input type="checkbox"/>	
UPS power test	<input type="checkbox"/>	<input type="checkbox"/>	
Trouble signals	<input type="checkbox"/>	<input type="checkbox"/>	
Disconnect switches	<input type="checkbox"/>	<input type="checkbox"/>	
Ground-fault monitoring	<input type="checkbox"/>	<input type="checkbox"/>	
CCU security mechanism	<input type="checkbox"/>	<input type="checkbox"/>	
Prerecorded message content	<input type="checkbox"/>	<input type="checkbox"/>	
Prerecorded message activation	<input type="checkbox"/>	<input type="checkbox"/>	
Software backup performed	<input type="checkbox"/>	<input type="checkbox"/>	
Test backup software	<input type="checkbox"/>	<input type="checkbox"/>	
Fire alarm to MNS interface	<input type="checkbox"/>	<input type="checkbox"/>	
MNS to fire alarm interface	<input type="checkbox"/>	<input type="checkbox"/>	
In-building MNS to wide-area MNS	<input type="checkbox"/>	<input type="checkbox"/>	

7. TESTING RESULTS (continued)

7.5 Mass Notification Equipment (continued)

Description	Visual Inspection	Functional Test	Comments
MNS to direct recipient MNS	<input type="checkbox"/>	<input type="checkbox"/>	
Sound pressure levels Occupied <input type="checkbox"/> Yes <input type="checkbox"/> No Ambient dBA Alarm dBA (attach report with locations, values, and weather conditions)	<input type="checkbox"/>	<input type="checkbox"/>	
System intelligibility <input type="checkbox"/> CSI <input type="checkbox"/> STI (attach report with locations, values, and weather conditions)	<input type="checkbox"/>	<input type="checkbox"/>	
Other (specify) _____	<input type="checkbox"/>	<input type="checkbox"/>	

7.6 Two-Way Communications Equipment

Description	Visual Inspection	Functional Test	Comments
Phone handsets	<input type="checkbox"/>	<input type="checkbox"/>	
Phone jacks	<input type="checkbox"/>	<input type="checkbox"/>	
Off-hook indicator	<input type="checkbox"/>	<input type="checkbox"/>	
Call-in signal	<input type="checkbox"/>	<input type="checkbox"/>	
System performance	<input type="checkbox"/>	<input type="checkbox"/>	
System audibility	<input type="checkbox"/>	<input type="checkbox"/>	
System intelligibility	<input type="checkbox"/>	<input type="checkbox"/>	
Radio communications enhancement system	<input type="checkbox"/>	<input type="checkbox"/>	
Area of refuge communication system	<input type="checkbox"/>	<input type="checkbox"/>	
Elevator emergency communications system	<input type="checkbox"/>	<input type="checkbox"/>	
Other (specify) _____	<input type="checkbox"/>	<input type="checkbox"/>	

7. TESTING RESULTS (continued)

7.7 Combination Systems

Description	Visual Inspection	Functional Test	Comments
Fire extinguishing monitoring devices/system	<input type="checkbox"/>	<input type="checkbox"/>	
Carbon monoxide detector/system	<input type="checkbox"/>	<input type="checkbox"/>	
Combination fire/security system	<input type="checkbox"/>	<input type="checkbox"/>	
Other (specify)	<input type="checkbox"/>	<input type="checkbox"/>	

7.8 Special Hazard Systems

Description (specify)	Visual Inspection	Functional Test	Comments
	<input type="checkbox"/>	<input type="checkbox"/>	
	<input type="checkbox"/>	<input type="checkbox"/>	
	<input type="checkbox"/>	<input type="checkbox"/>	

7.9 Emergency Communications System

- Visual
- Functional
- Simulated operation
- Ensure predischage notification appliances of special hazard systems are not overridden by the MNS. See *NFPA 72*, 24.4.1.7.1.

7.10 Monitored Systems

Description (specify)	Visual Inspection	Functional Test	Comments
Engine-driven generator	<input type="checkbox"/>	<input type="checkbox"/>	
Fire pump	<input type="checkbox"/>	<input type="checkbox"/>	
Special suppression systems	<input type="checkbox"/>	<input type="checkbox"/>	
Other (specify)	<input type="checkbox"/>	<input type="checkbox"/>	

7. TESTING RESULTS (continued)

7.11 Auxiliary Functions

Description	Visual Inspection	Functional Test	Comments
Door-releasing devices	<input type="checkbox"/>	<input type="checkbox"/>	
Fan shutdown	<input type="checkbox"/>	<input type="checkbox"/>	
Smoke management/smoke control	<input type="checkbox"/>	<input type="checkbox"/>	
Smoke damper operation	<input type="checkbox"/>	<input type="checkbox"/>	
Smoke shutter release	<input type="checkbox"/>	<input type="checkbox"/>	
Door unlocking	<input type="checkbox"/>	<input type="checkbox"/>	
Elevator recall	<input type="checkbox"/>	<input type="checkbox"/>	
Elevator shunt trip	<input type="checkbox"/>	<input type="checkbox"/>	
MNS override of FA signals	<input type="checkbox"/>	<input type="checkbox"/>	
Other (specify)	<input type="checkbox"/>	<input type="checkbox"/>	

7.12 Alarm Initiating Device

Device test results sheet attached listing all devices tested and the results of the testing

7.13 Supervisory Alarm Initiating Device

Device test results sheet attached listing all devices tested and the results of the testing

7.14 Alarm Notification Appliances

Appliance test results sheet attached listing all appliances tested and the results of the testing

7.15 Supervisory Station Monitoring

Description	Visual Inspection	Functional Test	Time	Comments
Alarm signal	<input type="checkbox"/>	<input checked="" type="checkbox"/>	10:15	
Alarm restoration	<input type="checkbox"/>	<input checked="" type="checkbox"/>	10:15	
Trouble signal	<input type="checkbox"/>	<input checked="" type="checkbox"/>	10:15	
Trouble restoration	<input type="checkbox"/>	<input checked="" type="checkbox"/>	10:15	
Supervisory signal	<input type="checkbox"/>	<input type="checkbox"/>		
Supervisory restoration	<input type="checkbox"/>	<input type="checkbox"/>		

8. NOTIFICATIONS THAT TESTING IS COMPLETE

Monitoring organization	Contact:	Centra	Time:	11:15
Building management	Contact:	Leslie	Time:	11:15
Building occupants	Contact:		Time:	
Authority having jurisdiction	Contact:	Fire Dept	Time:	11:15
Other, if required	Contact:		Time:	

9. SYSTEM RESTORED TO NORMAL OPERATION

Date: 5/4/17 Time:

10. CERTIFICATION

10.1 Inspector Certification:

This system, as specified herein, has been inspected and tested according to all NFPA standards cited herein.

Signed: *Brian Ewings* Printed name: BRIAN EWINGS Date: 5/4/17
Organization: Cunningham Title: Technician Phone: 207-846-3350

10.2 Acceptance by Owner or Owner's Representative:

The undersigned has a service contract for this system in effect as of the date shown below.

Signed: *Hannah White* Printed name: Hannah White Date: 5.4.17
Organization: Aroma Provisions Title: Catering Director Phone: 871-2060

DEVICE TEST RESULTS

(Attach additional sheets if required)

Device Type	Address	Location	Test Results
Pull Station	6	Main Entry	PASS
Smoke	3	Basement	PASS
Heat	4	Basement	PASS
Pull Station	6	Rear Exit	PASS
Heat	5	Store Front	PASS
Heat	5	Store Rear	PASS
Hood Suppression	6	Kitchen	PASS
Pull	7	Bakery	PASS
Hood Suppression	8	Bakers	PASS