



B9 ELECTRICAL GENERAL NOTES

- BRANCH CIRCUIT WIRING NOT SHOWN. EXISTING WIRING MAY, AT THE CONTRACTOR'S DISCRETION, REMAIN CONNECTED AND PROTECTED FROM WEATHER AND PHYSICAL DAMAGE DURING CONSTRUCTION UNLESS NOTED OTHERWISE OR PROHIBITED BY THE AUTHORITY HAVING JURISDICTION.
- UPON COMPLETION OF THE PROJECT, ALL WIRING AND CONDUITS WITHIN CEILING SPACES SHALL BE IDENTIFIED BY THE CONTRACTOR AND SHOWN ON THE LATEST EDITION OF THE NATIONAL ELECTRICAL CODE.
- WHERE EXISTING WIRING IS REMOVED AND REPLACED, MATCH EXISTING COLORING AS CLOSELY AS PERMITTED BY CURRENT CODES AND REGULATIONS.
- ALL REPAIR WIRING AND ELECTRICAL WORK SHALL FULLY COMPLY WITH THE LATEST EDITION OF THE NATIONAL ELECTRICAL CODE.
- REMOVE EXISTING ELECTRICAL ITEMS AS REQUIRED TO COMPLETE THE WORK OF DIVISION 16 AND TO FACILITATE THE WORK OF OTHER DIVISIONS, WHETHER THOSE ITEMS ARE INDICATED ON THIS PLAN OR NOT.
- PROVIDE A COMPLETE AND OPERATIONAL ELECTRICAL SYSTEM IN ALL AREAS INDICATED ON THIS DRAWING, WHETHER THOSE ITEMS ARE INDICATED ON THIS DRAWING OR NOT.
- ALL ELECTRICAL DEVICES, EQUIPMENT, FIXTURES, ETC. SHALL BE PROTECTED FROM DAMAGE DURING CONSTRUCTION.
- COORDINATE ALL ELECTRICAL WORK WITH THE WORK OF OTHER DIVISIONS.
- POWER WIRING FOR EQUIPMENT & CONTROL IS TO BE PERFORMED BY DIVISION 16. CONTROL WIRING BY DIVISION 15.
- NO WIRING OR CONDUIT THAT BECOMES UNUSED AS PART OF THIS PROJECT SHALL BE ABANDONED IN PLACE.

G9 ELECTRICAL LEGEND

NO SCALE

- CEILING MOUNTED HID LIGHT FIXTURE
- FLUORESCENT INDUSTRIAL STRIP LIGHT
- 208/120 VOLT, 3 PHASE PANELBOARD, SURFACE MOUNTED
- (E) EXISTING ITEM TO REMAIN
- (ER) EXISTING ITEM TO BE REMOVED AND REINSTALLED
- KEY NOTE
- EXISTING CONDUIT ~ TO BE REMOVED/RELOCATED AS INDICATED
- CONDUIT TURNING UP
- CONDUIT TURNING DOWN

E9 ELECTRICAL KEY NOTES

NO SCALE

- PROVIDE TEMPORARY SUPPORT FOR FACEWAY TO FACILITATE NEW ROOF CONSTRUCTION. PROVIDE PERMANENT SUPPORT UPON COMPLETION OF ROOF CONSTRUCTION.
- REMOVE AND REINSTALL WIRELESS CAMERA RECEIVERS AND ASSOCIATED CABLE AND HARDWARE TO FACILITATE NEW ROOF CONSTRUCTION.
- PROVIDE SUPPORTS AS REQUIRED TO ENSURE OVERHEAD ELECTRICAL REMAINS IN PLACE AND OPERATIONAL.

E-100

ELECTRICAL PLAN, NOTES AND LEGEND

REPLACE BAY #8 ROOF SYSTEM
F.M.S. #1
PORTLAND, MAINE

REVISIONS

NUMBER	DATE	BY	DESCRIPTION

Date: 03/10/2006
 Drawn By: CRH
 Checked By: SRM
 Project Mgr: WFF
 Project No: 06009
 Cad File: 06009E.DWG
 Graphic Scale: 0 1"
 © COPYRIGHT 2006 ALLIED ENGINEERING, INC.

Allied Engineering
 Structural Mechanical Electrical Commissioning

160 Veranda Street
 Portland, Maine 04103
 T: 207.221.2260
 F: 207.221.2266
 Web: www.allied-eng.com