

1

## Norm Daigle Carpentry & Painting

2 Westside Sebago Road

Standish, ME 04084

(207)650-4153

June 28, 2015


To Whom it May Concern:

In accordance with the International Residential Code 2009 requirements for decks,  
Deck at 39 Mayfield 04103 is:

- Faceted to ledger with 16-penny galvanized nails d 6" GRK galvanized screws, every 2'.
- 2x8 joist hangers on all joist
- Decking drip cap has been attached to ledger.

If you should have any additional questions, please give me a call at (207)650-4153.

Respectfully,



Norman R. Daigle