DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

SMALL SUSAN S & JEFFREY M SMALL

Located at

39 MAYFIELD ST

has permission to Install a viesmann 100 Boiler in basement

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ David Petruccelli /s/ Tammy Munson

Fire Official Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

Building Inspections

Fire Department
Classification:

One or Two Family Dwellings ENTIRE

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

REQUIRED INSPECTIONS:

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No:	Date Applied For:	CBL:	
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 8	74-8716	2015-00456	03/12/2015	145 B032001	
Proposed Use: Proposed Project Description:					
Single Family Home		Install a viesmann 100 Boiler in basement			
Dept: Zoning Status: Approved R	eviewer:	Tammy Munson	Approval Da	ite: 03/20/2015	
Note:				Ok to Issue: 🗹	
Conditions:					
Dept: Building Inspecti Status: Approved w/Conditions R Note:	eviewer:	Tammy Munson	Approval Da	te: 03/20/2015 Ok to Issue: 🗹	
Conditions:					
1) Equipment shall be installed in compliance with the manufacturer's specifications and the UL listing.					
Dept: Fire Status: Approved w/Conditions R Note:	eviewer:	David Petruccelli	• •	te: 03/13/2015 Ok to Issue: ✓	
Conditions: 1) Construction or installation shall comply with City Code Chapte.	r 10.				
2) Street addresses shall be marked on the structure and shall be as approved by the City E-911 Addressing Officer. Contact Michelle Sweeney at 874-8682 for further information.					

3) Carbon Monoxide is detection required in accordance with NFPA 720, Standard for Installation of Carbon Monoxide (CO)

- Detection and Warning Equipment, 2009 edition.
 4) All outstanding code violations shall be corrected prior to final inspection.
- 5) Any cutting and welding done will require a Hot Work Permit from Fire Department.
- 6) Shall meet the requirements of 2009 NFPA 1 Fire Code.