

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

UNIVERSITY OF NEW ENGLAND /High Tech Fire
Protection

PERMIT ID: 2013-00427

Located at

746 STEVENS AVE/ 1 COLLEGE AVE

CBL: 145 B042001

has permission to **install NFPA 13 supervised sprinkler system.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

B. Campbell

Fire Prevention Officer

(58)

Code Enforcement Officer / Plan Reviewer

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

City of Portland, Maine - Building or Use Permit Application

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 2013-00427	Issue Date:	CBL: 145 B042001
--------------------------	-------------	---------------------

Location of Construction: 746 STEVENS AVE/ 1 COLLEGE AVE	Owner Name: UNIVERSITY OF NEW ENGLAND	Owner Address: 11 HILLS BEACH RD BIDDEFORD, ME 04005		Phone:
Business Name: UNE	Contractor Name: High Tech Fire Protection	Contractor Address: P.O. Box 156 Minot ME 04258		Phone: (207) 998-2551
Lessee/Buyer's Name	Phone:	Permit Type: Fire Suppression Water Based		Zone: R5
Past Use: Patient Care / Dental Arts Facility for University Education	Proposed Use: Same: Patient Care / Dental Arts Facility for University Education	Permit Fee: \$1,100.00	Cost of Work: \$107,280.00	CEO District: 7
		FIRE DEPT: <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied <input type="checkbox"/> N/A <i>3/20/13</i>		INSPECTION: Use Group: Type:
Proposed Project Description: install water based fire suppression system in new Patient Care Facility		Signature: <i>[Signature]</i> Signature: <i>[Signature]</i> PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied Signature: Date:		

Permit Taken By: LDOBSON	Date Applied For: 03/04/2013	Zoning Approval		
1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules. 2. Building permits do not include plumbing, septic or electrical work. 3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..		Special Zone or Reviews <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan Maj <input type="checkbox"/> Minor <input type="checkbox"/> MM <input checked="" type="checkbox"/> Date: <i>3/4/13</i>	Zoning Appeal <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied Date:	Historic Preservation <input checked="" type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied Date: <i>[Signature]</i>

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE		DATE	PHONE

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**

REQUIRED INSPECTIONS:

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 2013-00427	Date Applied For: 03/04/2013	CBL: 145 B042001
---------------------------------	--	----------------------------

Location of Construction: 746 STEVENS AVE/ 1 COLLEGE	Owner Name: UNIVERSITY OF NEW ENGLAN	Owner Address: 11 HILLS BEACH RD	Phone:
Business Name: UNE	Contractor Name: High Tech Fire Protection	Contractor Address: P.O. Box 156 Minot	Phone (207) 998-2551
Lessee/Buyer's Name	Phone:	Permit Type: Fire Suppression Water Based	

Proposed Use: Same: Patient Care / Dental Arts Facility for University Education	Proposed Project Description: install NFPA 13 supervised sprinkler system.
--	--

Dept: Zoning **Status:** Approved **Reviewer:** Marge Schmuckal **Approval Date:** 03/04/2013
Note: **Ok to Issue:**

Dept: Fire **Status:** Approved w/Conditions **Reviewer:** Ben Wallace Jr **Approval Date:** 03/20/2013
Note: **Ok to Issue:**

- 1) Installation shall be in accordance with the City of Portland Fire Department Regulations and NFPA 13 as published. A copy of the State Sprinkler permit with RMS date and signature and the Contractor's Material and Test Certificate for Aboveground Piping (NFPA 13 figure 24.1) shall be provided prior to scheduling of the final inspection.
- 2) System acceptance and commissioning must be coordinated with alarm and suppression system contractors and the Fire Department. Call 874-8703 to schedule.
- 3) Fire department connection shall be two 2 1/2" inlets.
- 4) A Knox Box is required.
- 5) Sprinkler supervision shall be provided in accordance with NFPA 101, Life Safety Code, and NFPA 72, National Fire Alarm and Signaling Code.
- 6) Notice: The first scheduled final inspection fee is at no charge. Additional inspections shall be billed at \$75 for each inspector.
- 7) The entire sprinkler system shall be maintained in accordance with NFPA 25, Standard for Inspection, Testing and Maintenance of Water-Based Fire Protection Systems, 2008 edition.

Patent
Case CTR



Water-Based Fire Suppression System Permit

If you or the property owner owes real estate or property taxes or user charges on any property within the city, payment arrangements must be made before permits of any kind are accepted.

Installation address: One College Street CBL: 145-B-42

Exact location: (within structure) Entire Structure

Type of occupancy(s) (NFPA & ICC): Business / Educational

Building owner: University of New England

Managing Supervisor (RMS): Edward Poulin License No: 515

Supervisor phone: (207) 998-2551 E-mail: EPoulin@fairpoint.net

Installing contractor: High Tech Fire Protection License No: 102

Contractor phone: (207) 998-2551 E-mail: HTFP@fairpoint.net

The suppression work to be done will be: New: Renovation: Addition to existing system:

This is an amendment to an existing permit: Yes: NO: Permit no: _____

NFPA Standard this system is designed to: 13 Edition: 2010

*Non-NFPA systems are not approved for use within the City of Portland.

Download a new copy of this document from www.portlandmaine.gov/fire for every submittal. Attach all working documents and complete approved submittals as may be required by the State Fire Marshal's Office on electronic PDF's in addition to full sized plans.

Contractor shall verify location and type of all FDCs shall be approved in writing by the Fire Prevention Bureau.

COST OF WORK: \$107,280.00
PERMIT FEE: \$1,100
 (\$10 PER \$1,000 + \$30 FOR THE FIRST \$1,000)

RECEIVED
 MAR 04 2013
 Dept. of Building Inspections
 City of Portland Maine

Submit all information to the Building Inspections Department, 389 Congress Street, Room 315, Portland, Maine 04101.

Prior to acceptance of any fire protection system, a complete commissioning and acceptance test must be coordinated with all fire system contractors and the Fire Department, and proper documentation of such test(s) provided.

All installation(s) must comply with NFPA and the Fire Department Technical Standard(s).

Applicant signature: _____ Date: 02/26/2013

Jeremy Foss - Jfoss@Fairpoint.net



... Fire Protection by Computer Design

High Tech Fire Protection
84 Hackett Mills Road
P.O. Box 156
Minot, Maine 04258-0156
998-2551

Job Name : First Floor Calc.
Drawing : FP-02
Location : 1 College Street
Remote Area :
Contract : 080212-1
Data File : First Floor Calc.wxf


Water Supply Curve (C)

High Tech Fire Protection
First Floor Calc.

Page 1
Date 02/26/2013

City Water Supply:
C1 - Static Pressure : 56
C2 - Residual Pressure: 54
C2 - Residual Flow : 1034

Demand:
D1 - Elevation : 6.930
D2 - System Flow : 139.943
D2 - System Pressure : 41.232
Hose (Adj City) : _____
Hose (Demand) : 100
D3 - System Demand : 239.943
Safety Margin : 14.634



Fittings Used Summary

High Tech Fire Protection
First Floor Calc.

Page 2
Date 02/26/2013

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24	
AI	Alarm Viking J1								10		13		20	23								
B	Generic Butterfly Valve	0	0	0	0	7	7	7	10	0	12	9	10	12	19	21	0	0	0	0	0	0
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																				
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	
V	90' Ell Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0	
X	90'Tee-BranchFirelock002	0	0	0	0	0	8.5	10.8	13	0	16	21	25	33	0	0	0	0	0	0	0	
Zia	Wilkins 350	Fitting generates a Fixed Loss Based on Flow																				

Pressure / Flow Summary - STANDARD

High Tech Fire Protection
First Floor Calc.

Page 3
Date 02/26/2013

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
DP1	-1.5	5.6	16.14	na	22.5	0.1	225	7.0
DP2	-1.5	5.6	16.14	na	22.5	0.1	225	7.0
401	24.0	K = K @ EQ01	21.38	na	24.08			
A1	24.0		23.0	na				
402	24.0	K = K @ EQ01	21.41	na	24.1			
A2	24.0		23.02	na				
A3	24.0		23.64	na				
A4	23.0		24.2	na				
403	24.0	K = K @ EQ01	18.67	na	22.5			
404	24.0	K = K @ EQ02	20.61	na	23.34			
406	24.0	K = K @ EQ01	18.74	na	22.54			
407	24.0	K = K @ EQ02	20.69	na	23.38			
A6	24.0		21.86	na				
A7	24.0		21.94	na				
A8	24.0		23.64	na				
A9	23.0		24.24	na				
A5	23.0		24.33	na				
A10	23.0		24.79	na				
A11	8.0		31.41	na				
Z3	8.0		34.79	na				
TOR	8.0		34.8	na				
BOR	3.0		38.0	na				
BASE	3.0		43.29	na				
H1	3.0		43.38	na				
TEST	8.0		41.23	na	100.0			

The maximum velocity is 9.85 and it occurs in the pipe between nodes 407 and A7

Final Calculations - Hazen-Williams

High Tech Fire Protection
First Floor Calc.

Page 4
Date 02/26/2013


Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
DP1 to EQ01	22.50 22.5	1.049 120 0.1618	1E 1Eq	2.0 18.0 0.0	0.500 20.000 20.500	16.143 -0.794 3.317			K Factor = 5.60 Vel = 8.35	
	0.0 22.50						18.666		K Factor = 5.21	
DP2 to EQ02	22.50 22.5	1.049 120 0.1618	1T 1Eq	5.0 18.0 0.0	0.500 23.000 23.500	16.143 -0.794 3.803			K Factor = 5.60 Vel = 8.35	
	0.0 22.50						19.152		K Factor = 5.14	
401 to A1	24.08 24.08	1.049 120 0.1834	1T	5.0 0.0 0.0	3.800 5.000 8.800	21.384 0.0 1.614			K Factor @ node EQ01 Vel = 8.94	
A1 to A2	0.0 24.08	2.635 120 0.0021		0.0 0.0 0.0	12.000 0.0 12.000	22.998 0.0 0.025			Vel = 1.42	
	0.0 24.08						23.023		K Factor = 5.02	
402 to A2	24.10 24.1	1.049 120 0.1836	1T	5.0 0.0 0.0	3.800 5.000 8.800	21.407 0.0 1.616			K Factor @ node EQ01 Vel = 8.95	
A2 to A3	24.08 48.18	2.635 120 0.0075	1X	14.827 0.0 0.0	67.900 14.827 82.727	23.023 0.0 0.617			Vel = 2.83	
A3 to A4	0.0 48.18	2.635 120 0.0075	1T	16.474 0.0 0.0	1.000 16.474 17.474	23.640 0.433 0.131			Vel = 2.83	
A4 to A5	0.0 48.18	3.26 120 0.0026	1X	17.471 0.0 0.0	29.600 17.471 47.071	24.204 0.0 0.124			Vel = 1.85	
	0.0 48.18						24.328		K Factor = 9.77	
*P										
403 to 404	22.50 22.5	1.049 120 0.1618		0.0 0.0 0.0	12.000 0.0 12.000	18.666 0.0 1.942			K Factor @ node EQ01 Vel = 8.35	
404 to A6	23.34 45.84	1.38 120 0.1587	1T	6.0 0.0 0.0	1.900 6.000 7.900	20.608 0.0 1.254			K Factor @ node EQ02 Vel = 9.83	
	0.0 45.84						21.862		K Factor = 9.80	
*P										
406 to 407	22.54 22.54	1.049 120 0.1623		0.0 0.0 0.0	12.000 0.0 12.000	18.737 0.0 1.948			K Factor @ node EQ01 Vel = 8.37	
407 to A7	23.39 45.93	1.38 120 0.1594	1T	6.0 0.0 0.0	1.900 6.000 7.900	20.685 0.0 1.259			K Factor @ node EQ02 Vel = 9.85	

Final Calculations - Standard

High Tech Fire Protection
First Floor Calc.

Page 5
Date 02/26/2013

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 45.93					21.944		K Factor = 9.80	
*P									
A6 to A7	45.84 45.84	2.635 120 0.0068		0.0 0.0 0.0	12.000 0.0 12.000	21.862 0.0 0.082		Vel = 2.70	
A7 to A8	45.93 91.77	2.635 120 0.0246	1V	5.903 0.0 0.0	63.200 5.903 69.103	21.944 0.0 1.698		Vel = 5.40	
A8 to A9	0.0 91.77	2.635 120 0.0245	1V	5.903 0.0 0.0	1.000 5.903 6.903	23.642 0.433 0.169		Vel = 5.40	
A9 to A5	0.0 91.77	2.635 120 0.0247		0.0 0.0 0.0	3.400 0.0 3.400	24.244 0.0 0.084		Vel = 5.40	
A5 to A10	48.17 139.94	4.26 120 0.0052	1X 1V	21.067 8.954 0.0	60.000 30.021 90.021	24.328 0.0 0.465		Vel = 3.15	
A10 to A11	0.0 139.94	4.26 120 0.0052	1V	8.954 0.0 0.0	15.000 8.954 23.954	24.793 6.496 0.125		Vel = 3.15	
A11 to Z3	0.0 139.94	4.26 120 0.0052	2V 1Fsp 1B 1T	17.907 0.0 15.8 26.334	13.100 60.041 73.141	31.414 0.0 0.378		* Fixed loss = 3 Vel = 3.15	
Z3 to TOR	0.0 139.94	6.357 120 0.0007	1V	12.573 0.0 0.0	3.500 12.573 16.073	34.792 0.0 0.012		Vel = 1.41	
TOR to BOR	0.0 139.94	6.357 120 0.0007	1Fsp 1AI 1V	0.0 25.147 12.573	5.000 37.720 42.720	34.804 3.166 0.031		* Fixed loss = 1 Vel = 1.41	
BOR to BASE	0.0 139.94	6.357 120 0.0008	1E 1Zia	17.603 0.0 0.0	4.900 17.603 22.503	38.001 5.269 0.017		* Fixed loss = 5.269 Vel = 1.41	
BASE to H1	0.0 139.94	6.16 120 0.0009	1G 1T	3.236 32.359 0.0	70.000 35.595 105.595	43.287 0.0 0.090		Vel = 1.51	
H1 to TEST	0.0 139.94	8.27 120 0.0002	1E 1G 1T	21.405 4.757 41.62	30.000 67.782 97.782	43.377 -2.166 0.021		Vel = 0.84	
	100.00 239.94					41.232		Qa = 100.00 K Factor = 37.37	



... Fire Protection by Computer Design

High Tech Fire Protection
84 Hackett Mills Road
P.O. Box 156
Minot, Maine 04258-0156
998-2551

Job Name : Second Floor Calc. (Revised)
Drawing : FP-03
Location : 1 College Street
Remote Area : #2
Contract : 080212-1
Data File : Second Floor Calc.wxf


Water Supply Curve (C)

High Tech Fire Protection
Second Floor Calc. (Revised)

Page 1
Date 02/26/2013

City Water Supply:
C1 - Static Pressure : 56
C2 - Residual Pressure: 54
C2 - Residual Flow : 1034

Demand:
D1 - Elevation : 12.993
D2 - System Flow : 185.601
D2 - System Pressure : 50.602
Hose (Adj City) : _____
Hose (Demand) : 100
D3 - System Demand : 285.601
Safety Margin : 5.213



Fittings Used Summary

High Tech Fire Protection
Second Floor Calc. (Revised)

Page 2
Date 02/26/2013

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24	
Al	Alarm Viking J1								10		13		20	23								
B	Generic Butterfly Valve	0	0	0	0	7	7	7	10	0	12	9	10	12	19	21	0	0	0	0	0	0
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																				
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	
V	90' Ell Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0	
X	90'Tee-BranchFirelock002	0	0	0	0	0	8.5	10.8	13	0	16	21	25	33	0	0	0	0	0	0	0	
Zia	Wilkins 350	Fitting generates a Fixed Loss Based on Flow																				

Final Calculations - Hazen-Williams

High Tech Fire Protection
Second Floor Calc. (Revised)

Page 4
Date 02/26/2013

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
DP1 to EQ01	22.50 22.5	1.049 120 0.1618	2E 1T	4.0 5.0 0.0	2.000 9.000 11.000	16.143 -0.433 1.780			K Factor = 5.60 Vel = 8.35	
	0.0 22.50						17.490		K Factor = 5.38	
10 to 11	22.50 22.5	1.61 120 0.0201		0.0 0.0 0.0	12.000 0.0 12.000	17.490 0.0 0.241			K Factor @ node EQ01 Vel = 3.55	
11 to 12	22.65 45.15	1.61 120 0.0729		0.0 0.0 0.0	12.000 0.0 12.000	17.731 0.0 0.875			K Factor @ node EQ01 Vel = 7.12	
12 to 13	23.21 68.36	1.61 120 0.1569		0.0 0.0 0.0	12.000 0.0 12.000	18.606 0.0 1.883			K Factor @ node EQ01 Vel = 10.77	
13 to B1	24.35 92.71	1.61 120 0.2758	1T	8.0 0.0 0.0	5.600 8.000 13.600	20.489 0.0 3.751			K Factor @ node EQ01 Vel = 14.61	
	0.0 92.71						24.240		K Factor = 18.83	
*P										
20 to 21	22.54 22.54	1.61 120 0.0201		0.0 0.0 0.0	12.000 0.0 12.000	17.556 0.0 0.241			K Factor @ node EQ01 Vel = 3.55	
21 to 22	22.70 45.24	1.61 120 0.0732		0.0 0.0 0.0	12.000 0.0 12.000	17.797 0.0 0.878			K Factor @ node EQ01 Vel = 7.13	
22 to 23	23.25 68.49	1.61 120 0.1575		0.0 0.0 0.0	12.000 0.0 12.000	18.675 0.0 1.890			K Factor @ node EQ01 Vel = 10.79	
23 to B2	24.40 92.89	1.61 120 0.2768	1T	8.0 0.0 0.0	5.600 8.000 13.600	20.565 0.0 3.764			K Factor @ node EQ01 Vel = 14.64	
	0.0 92.89						24.329		K Factor = 18.83	
*P										
B1 to B2	92.71 92.71	3.26 120 0.0089		0.0 0.0 0.0	10.000 0.0 10.000	24.240 0.0 0.089			Vel = 3.56	
B2 to B3	92.89 185.6	3.26 120 0.0321	1X	17.471 0.0 0.0	31.900 17.471 49.371	24.329 0.0 1.584			Vel = 7.13	
B3 to B4	0.0 185.6	3.26 120 0.0321	1X	17.471 0.0 0.0	72.400 17.471 89.871	25.913 0.0 2.882			Vel = 7.13	
B4 to B5	0.0 185.6	4.26 120 0.0087	2V	17.907 0.0 0.0	49.100 17.907 67.007	28.795 0.0 0.584			Vel = 4.18	

Final Calculations - Standard

High Tech Fire Protection
Second Floor Calc. (Revised)

Page 5
Date 02/26/2013

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
B5 to B6	0.0 185.6	4.26 120 0.0087	1V	8.954 0.0 0.0	30.000 8.954 38.954	29.379 12.993 0.340		Vel = 4.18	
B6 to Z2	0.0 185.6	4.26 120 0.0087	1B 1Fsp 1V 1X	15.8 0.0 8.954 21.067	33.900 45.821 79.721	42.712 3.000 0.695		* Fixed loss = 3 Vel = 4.18	
Z2 to TOR	0.0 185.6	6.357 120 0.0012	1V	12.573 0.0 0.0	5.600 12.573 18.173	46.407 0.0 0.022		Vel = 1.88	
TOR to BOR	0.0 185.6	6.357 120 0.0012	1Fsp 1Al 1V	0.0 25.147 12.573	5.000 37.720 42.720	46.429 3.166 0.053		* Fixed loss = 1 Vel = 1.88	
BOR to BASE	0.0 185.6	6.357 120 0.0012	1E 1Zia	17.603 0.0 0.0	4.900 17.603 22.503	49.648 2.906 0.027		* Fixed loss = 2.906 Vel = 1.88	
BASE to H1	0.0 185.6	6.16 120 0.0014	1G 1T	3.236 32.359 0.0	70.000 35.595 105.595	52.581 0.0 0.153		Vel = 2.00	
H1 to TEST	0.0 185.6	8.27 120 0.0003	1E 1G 1T	21.405 4.757 41.62	30.000 67.782 97.782	52.734 -2.166 0.034		Vel = 1.11	
	100.00 285.60					50.602		Qa = 100.00 K Factor = 40.15	