

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 09-0048	Date Applied For: 01/22/2009	CBL: 146 A018001
------------------------------	--	----------------------------

Location of Construction: 1026 FOREST AVE	Owner Name: HERRING HILL ASSOCIATES	Owner Address: 18 MERRILL RD	Phone: 207-883-4317
Business Name:	Contractor Name: Portland Pump Co.	Contractor Address: P.O. Box 1180 Mussey Rd. Ext. Scarb	Phone: (207) 883-4317
Lessee/Buyer's Name	Phone:	Permit Type: Tanks - Removal	

Proposed Use: Commercial -Remove 500 gallon underground fuel tank (oil)	Proposed Project Description: Remove 500 gallon underground fuel tank (oil)
---	---

Dept: Zoning	Status: Approved	Reviewer: Ann Machado	Approval Date: 01/22/2009
Note:	Ok to Issue: <input checked="" type="checkbox"/>		
Dept: Building	Status: Approved with Conditions	Reviewer: Chris Hanson	Approval Date: 02/04/2009
Note:	Ok to Issue: <input checked="" type="checkbox"/>		
1) Installation shall comply with 2003 International Mechanical Code and State of Maine Oil and Solid Fuel Board Laws and Rules			
Dept: Fire	Status: Approved	Reviewer: Capt Keith Gautreau	Approval Date: 01/29/2009
Note:	Ok to Issue: <input checked="" type="checkbox"/>		
1) Tank removal shall comply with NFPA # 1 chapter 66.2.5.5 and NFPA 30. A copy is available upon request.			