



SITE PLAN GENERAL NOTES

- A. PROVIDE A COMPLETE & OPERATING SYSTEM. ALL ITEMS ARE NOT NECESSARILY SHOWN.
- B. CONTRACTOR IS RESPONSIBLE FOR SITE INVESTIGATION PRIOR TO START OF WORK TO REVEAL THE FULL SCOPE OF WORK.
- C. REVIEW ALL CIVIL DRAWINGS AND COORDINATE EXISTING CONDUIT ROUTES WITH LANDLORD PRIOR TO PLACING BID AND/OR COMMENCING WORK.
- D. SEE ARCHITECTURAL SHEETS FOR FURTHER SIGNAGE INFORMATION AND EXACT LOCATIONS.
- E. EXTERIOR SITE LIGHTING TO BE ON A PHOTO-ELECTRICAL CELL.
LIGHTING REQUIREMENTS:
 - 1. MINIMUM LIGHT LEVELS OF 1.5 FOOT CANDLES AT 30" AFF IN PATIO AREAS.
 - 2. MINIMUM LIGHT LEVELS OF 1.5 FOOT CANDLES AT PAVED AREAS.
 - 3. NO DARK AREAS ON SITE, INCLUDING TRASH ENCLOSURE.
 - 4. LED LIGHTING PREFERRED.
- I. LANDLORD PROVIDED AND INSTALLED CONDUITS SHALL HAVE OPENINGS PROTECTED AND PULLWIRES LABELED SO VENDORS WILL KNOW WHICH CONDUITS TO USE.
- J. FURNISH AND INSTALL APPROPRIATE HAND HOLES WHERE NEEDED AND PER CODE TO INSTALL CABLE/WIRE.
- K. INCREASE SIZE OF CONDUCTORS INDICATED IF NEEDED TO ACCOUNT FOR VOLTAGE DROP.

SITE PLAN SHEET NOTES

- 1. DRIVE-THRU DIRECTIONAL SIGNAGE: NEW SIGNAGE TO REPLACE EXISTING IN SAME LOCATION. E.C. SHALL EXTEND EXISTING CIRCUITRY AND MAKE FINAL CONNECTION. SIGNAGE SHALL BE CONTROLLED VIA TIMECLOCK.
- 2. PROVIDE ROUGH-IN AND FINAL CONNECTION TO WALL MOUNTED DRIVE THRU ORDER SCREEN. SEVEN (7) TOTAL PENETRATIONS (6 @ 3" AND 1 @ 3") - COORDINATE EXACT ROUGH-IN LOCATION IN FIELD PRIOR TO COMMENCING WORK. SEE ARCHITECTURAL FOR MORE INFORMATION. COORDINATE ROUTING OF CONDUIT IN FIELD. COORDINATE WITH OWNER AND STARBUCKS REPRESENTATIVE PRIOR TO COMMENCING WORK.
- 3. PROVIDE ROUGH-IN AND FINAL CONNECTION TO WALL MOUNTED DRIVE THRU 3 PANEL MENUBOARD. COORDINATE EXACT ROUGH-IN LOCATION IN FIELD PRIOR TO COMMENCING WORK. SEE ARCHITECTURAL FOR MORE INFORMATION. COORDINATE ROUTING OF CONDUIT IN FIELD. COORDINATE WITH OWNER AND STARBUCKS REPRESENTATIVE PRIOR TO COMMENCING WORK.

RESPONSIBILITY LEGEND	
GC	GENERAL CONTRACTOR
LL	LANDLORD
VD	VENDOR
WH	WAREHOUSE

EXTERIOR SIGNAGE SCHEDULE - "S"					
DESIGN ID	COUNT	DESCRIPTION	FURNISH	INSTALL	COMMENTS
SIGNAGE - DRIVE THRU					
14091	1	SIGN - DT DIRECTIONAL EXIT SIGN ILLUMINATED ARROW SERIES - 46IN 1170MM	VD	VD	HME. GC TO COORDINATE FINAL SET UP WITH STARBUCKS VENDOR. INSTALL OVER EXISTING FOOTING.
14327	1	SIGN - DT DIRECTIONAL ILLUMINATED ARROW SERIES - 46IN 1170MM	VD	VD	HME. GC TO COORDINATE FINAL SET UP WITH STARBUCKS VENDOR. INSTALL OVER EXISTING FOOTING.

SITE SCHEDULE - "Y"					
DESIGN ID	COUNT	DESCRIPTION	FURNISH	INSTALL	COMMENTS
EXTERIOR MENU					
14087	1	MENU BOARD - DT DIGITAL ORDER SCREEN WALL MOUNT HARDWARE - FLAT BLACK MT0028	VD	VD	DSA PHOTOTECH. PROVIDED & INSTALLED BY SIGNAGE VENDOR.
14114	1	MENU BOARD - DT 3 PANEL WALL MOUNTED - 72X48IN 1830X1220MM - FLAT BLACK MT0028	VD	VD	DSA PHOTOTECH. PROVIDED & INSTALLED BY SIGNAGE VENDOR.
14116	1	MENU BOARD - DT DIGITAL ORDER SCREEN - FLAT BLACK MT0028	VD	VD	DSA PHOTOTECH. PROVIDED & INSTALLED BY SIGNAGE VENDOR.

1 ELECTRICAL SITE PLAN
Scale: 1/8" = 1'-0"



ISSUED FOR CONSTRUCTION - 08/23/2017



STARBUCKS COFFEE COMPANY
2401 UTAH AVENUE SOUTH
SEATTLE, WASHINGTON 98134
(206) 318-1575

THESE DRAWINGS AND SPECIFICATIONS ARE CONFIDENTIAL AND SHALL REMAIN THE SOLE PROPERTY OF STARBUCKS CORPORATION, WHICH IS THE OWNER OF THE COPYRIGHT IN THIS WORK. THEY SHALL NOT BE REPRODUCED (IN WHOLE OR IN PART), SHARED WITH THIRD PARTIES OR USED IN ANY MANNER ON OTHER PROJECTS OR EXTENSIONS TO THIS PROJECT WITHOUT THE PRIOR WRITTEN CONSENT OF STARBUCKS CORPORATION. THESE DRAWINGS AND SPECIFICATIONS ARE INTENDED TO EXPRESS DESIGN INTENT FOR A PROTOTYPICAL STARBUCKS STORE (WHICH IS SUBJECT TO CHANGE AT ANYTIME) AND DO NOT REFLECT ACTUAL SITE CONDITIONS. NEITHER PARTY SHALL HAVE ANY OBLIGATION NOR LIABILITY TO THE OTHER (EXCEPT STATED ABOVE) UNTIL A WRITTEN AGREEMENT IS FULLY EXECUTED BY BOTH PARTIES.

STARBUCKS TEMPLATE VERSION I2016.12.23

NORR
ARCHITECTS PLANNERS
325 N. LESLIE ST., SUITE 500 | CHICAGO, IL 60654
1.312.424.2400 | www.norr.com

ENGINEER OF RECORD
William J. Alkemyer, P.E.
353 Marshall Avenue
St. Louis, Missouri 63119
Phone (314) 772-1782
Fax (314) 772-0708
Engineering Consultant

PROJECT NAME:
RENOVATION OF STARBUCKS COFFEE PORTLAND, 1080 FOREST AVENUE.
PROJECT ADDRESS:
1080 FOREST AVENUE
PORTLAND, ME 04103
CUMBERLAND COUNTY

STORE #: 11917
PROJECT #: 37548-037
ISSUE DATE: 08/04/2017
PROGRAM MANAGER: J. BOND
DESIGNER: A. LEE
LEED AP: R. TURNER-LAUCK
PRODUCTION DESIGNER: E. VEGA
CHECKED BY: BMS / SWE

Revision Schedule			
Rev	Date	By	Description

SHEET TITLE:
ELECTRICAL SITE PLAN

SCALE: AS SHOWN

SHEET NUMBER:
E-1001