

Curtis Walter Stewart
A r c h i t e c t s

434 Cumberland Avenue
Portland ME 04101-2325

Phone: 207.774.4441
Fax: 207.774.4016

Addendum 02

Date: March 29, 2002

To: Allied/Cook Construction, Inc.
From: Ben Walter, CWS Architects
Regarding: Exterior Renovations to The Park Danforth
Subject: Addendum 02

The following addendum items apply to the project known as Exterior Renovations to The Park Danforth located in Portland, Maine.

Modify the Contract Documents including 1) the Project Manual and Specifications dated March 11, 2002 and 2) the Drawings dated March 11, 2002 and Addendum 01 dated March 27, 2002 as follows:

1. Delete Clarification Item 5 from Addendum 01.
2. In Architectural Item 4 in Addendum 01, the fourth line "New steel (Clean by SP-6)" refers to new structural steel embedded in masonry, primarily specified in the location of the new balcony railing system, but also where new embedded steel may be required to modify steel relieving angles as per Detail 9/S5 and any new or replacement steel relieving angles that may be required. The second paint system indicated in Item 4 of Addendum 01, starting at line eight, is intended primarily for new exposed steel, primarily the balcony guard rails and loose steel lintels. Thus, modify line nine to read "~~New Relieving Angles~~ Loose Steel Lintels (Clean by SP-6)".

End of Addendum 02