



Graphic Scale: 1" = 12' 0"

The Park Danforth

777 Stevens Ave, Portland, ME, 04103

NO.	DESCRIPTION	DATE
1	Addendum No 2	2015-06-25



CONTENT:	
SCHEDULES	
DRAWN BY:	DRDLW
PROJECT NO:	12-056-00
DATE:	6/9/2015
REVISED:	
SCALE:	NO SCALE

E6.3

Project Phase
100% CONSTRUCTION DRAWINGS

COPYRIGHT © 2014 BY LAVALLÉE BRENSINGER PROFESSIONAL ASSOCIATION. ALL RIGHTS RESERVED. NO REPRODUCTION WITHOUT PERMISSION.

PANEL SCHEDULE - GS2									
VOLTAGE: 208/120V 3-PHASE, 4-WIRE				MLO: 100A MCB:			AIC: 65KA		
CIRCUIT BREAKER				CIRCUIT LOAD (KVA) CONNECTED			BRANCH CIRCUIT DESCRIPTION		
CKT NO	BRKR SIZE	NO OF POLES	PH	A	B	C			
1	20	1	A	0.00			SPARE		
3	20	1	B		0.00		SPARE		
5	20	1	C			0.00	SPARE		
7	20	1	A	0.00			SPARE		
9	20	1	B		0.00		SPARE		
11	20	1	C			0.00	SPARE		
13	20	1	A	0.00			SPARE		
15	20	1	B		0.00		SPARE		
17	20	1	C			0.00	SPARE		
19	20	1	A	0.00			SPARE		
21	20	1	B		0.00		SPARE		
23	20	1	C			0.00	SPARE		
25	20	1	A	0.00			SPARE		
27	20	1	B		0.00		SPARE		
29	20	1	C			0.00	SPARE		
31	20	1	A	0.00			SPARE		
33	20	1	B		0.00		SPARE		
35	20	1	C			0.00	SPARE		
37	20	1	A	0.00			SPARE		
39	20	1	B		0.00		SPARE		
41	20	1	C			0.00	SPARE		
SUBTOTAL				0.00	0.00	0.00			

PANEL SCHEDULE - CS1									
VOLTAGE: 208/120V 3-PHASE, 4-WIRE				MLO: 100A MCB:			AIC: 10KA		
CIRCUIT BREAKER				CIRCUIT LOAD (KVA) CONNECTED			BRANCH CIRCUIT DESCRIPTION		
CKT NO	BRKR SIZE	NO OF POLES	PH	A	B	C			
1	20	1	A	1.00			132 MECH CONTROL		
3	20	1	B		1.00		132A ERU REMOTE PANEL		
5	20	1	C			1.00	145 MECH CONTROL		
7	20	1	A	1.00			151 MECH CONTROL		
9	20	1	B		0.00		SPARE		
11	20	1	C			0.00	SPARE		
13	20	1	A	0.00			SPARE		
15	20	1	B		0.00		SPARE		
17	20	1	C			0.00	SPARE		
19	20	1	A	0.00			SPARE		
21	20	1	B		0.00		SPARE		
23	20	1	C			0.00	SPARE		
25	20	1	A	0.00			SPARE		
27	20	1	B		0.00		SPARE		
29	20	1	C			0.00	SPARE		
SUBTOTAL				2.00	1.00	1.00			
2	20	1	A	0.80			CUL-3 CUL-2		
4	20	1	B		0.80		REC: 132A SERVER ROOM		
6	20	2	C			0.00	REC: SERVER RACK		
8	20	1	A	0.00					
10	20	2	B		0.00		REC: SERVER RACK		
12	20	1	C			0.00			
14	20	1	A	1.00			FIRE SUPPRESSION SYSTEM 132A		
16	20	1	B		0.00		SPARE		
18	20	1	C			0.00	SPARE		
20	20	1	A	0.00			SPARE		
22	20	1	B		0.00		SPARE		
24	20	1	C			0.00	SPARE		
26	20	1	A	0.00			SPARE		
28	20	1	B		0.00		SPARE		
30	20	1	C			0.00	SPARE		
SUBTOTAL				1.80	0.90	0.00			

PANEL SCHEDULE - DP1									
VOLTAGE: 208/120V 3-PHASE, 4-WIRE				MLO: 400A MCB:			AIC: 42KA		
CIRCUIT BREAKER				CIRCUIT LOAD (KVA) CONNECTED			BRANCH CIRCUIT DESCRIPTION		
CKT NO	BRKR SIZE	NO OF POLES	PH	A	B	C			
1			A	9.94			PANEL 1N1		
3	225	3	B		11.68				
5			C			8.66			
7			A	9.29			APT 1103		
9	100	2	B		6.72				
11			C			9.29	APT 1105		
13	100	2	A	6.72			APT 1107		
15	100	2	B		9.29				
17	20	1	C			6.72			
19	20	1	A	0.00			SPARE		
21	20	1	B		0.00		SPARE		
23	20	1	C			0.00	SPARE		
25	20	1	A	0.00			SPARE		
27	20	1	B		0.00		SPARE		
29	20	1	C			0.00	SPARE		
31	20	1	A	0.00			SPARE		
33	20	1	B		0.00		SPARE		
35	20	1	C			0.00	SPARE		
37	20	1	A	0.00			SPARE		
39	20	1	B		0.00		SPARE		
41	20	1	C			0.00	SPARE		
SUBTOTAL				25.95	27.69	24.67			
2	100	2	A	9.29			APT 1108		
4			B		6.72				
6	100	2	C			9.29	APT 1109		
8			A	6.72					
10	100	2	B		9.29		APT 1110		
12	20	1	C			6.72			
14	100	2	A	9.29			APT 1111		
16	20	1	B		6.72				
18	100	2	C			9.56	APT 1112 (TYPE B)		
20	20	1	A	9.19					
22	20	1	B		0.00		SPARE		
24	20	1	C			0.00	SPARE		
26	20	1	A	0.00			SPARE		
28	20	1	B		0.00		SPARE		
30	20	1	C			0.00	SPARE		
32	20	1	A	0.00			SPARE		
34	20	1	B		0.00		SPARE		
36	20	1	C			0.00	SPARE		
38	20	1	A	0.00			SPARE		
40	20	1	B		0.00		SPARE		
42	20	1	C			0.00	SPARE		
SUBTOTAL				34.49	22.73	25.57			

PANEL SCHEDULE - 2N1									
VOLTAGE: 208/120V 3-PHASE, 4-WIRE				MLO: 100A MCB:			AIC: 22KA		
CIRCUIT BREAKER				CIRCUIT LOAD (KVA) CONNECTED			BRANCH CIRCUIT DESCRIPTION		
CKT NO	BRKR SIZE	NO OF POLES	PH	A	B	C			
1	20	1	A	1.26			REC: 2003, 2011, 2012, ST-B		
3	20	1	B		0.50		LTO: 2004, 2005, 2007, 2002, 2008A, 2008B, 2009, 2010		
5	20	1	C			0.50	2010 AUTO DOOR		
7	20	1	A	0.00			SPARE		
9	20	1	B		0.00		SPARE		
11	20	1	C			0.00	SPARE		
13	20	1	A	0.00			SPARE		
15	20	1	B		0.00		SPARE		
17	20	1	C			0.00	SPARE		
19	20	1	A	0.00			SPARE		
21	20	1	B		0.00		SPARE		
23	20	1	C			0.00	SPARE		
25	20	1	A	0.00			SPARE		
27	20	1	B		0.00		SPARE		
29	20	1	C			0.00	SPARE		
SUBTOTAL				1.26	0.50	0.50			
2	20	1	A	1.08			REC: 2002, 2007, 2008, 2009, 2010		
4	20	1	B		1.26		REC: 2000, 2001, ST-A, 2005, 2006,		
6	20	1	C			1.26	REC: 2004		
8	20	1	A	0.00			SPARE		
10	20	1	B		0.00		SPARE		
12	20	1	C			0.00	SPARE		
14	20	1	A	0.00			SPARE		
16	20	1	B		0.00		SPARE		
18	20	1	C			0.00	SPARE		
20	20	1	A	0.00			SPARE		
22	20	1	B		0.00		SPARE		
24	20	1	C			0.00	SPARE		
26	20	1	A	0.00			SPARE		
28	20	1	B		0.00		SPARE		
30	20	1	C			0.00	SPARE		
SUBTOTAL				1.08	1.26	1.26			

PANEL SCHEDULE - 1N1									
VOLTAGE: 208/120V 3-PHASE, 4-WIRE				MLO: 225 MCB:			AIC: 42		
CIRCUIT BREAKER				CIRCUIT LOAD (KVA) CONNECTED			BRANCH CIRCUIT DESCRIPTION		
CKT NO	BRKR SIZE	NO OF POLES	PH	A	B	C			
1	20	1	A	0.90			REC: 1011, 1012, 1013, 1013A, 1014		
3	20	1	B		1.44		REC: 1009F		
5	20	1	C			1.26	REC: 1009F, 1009G		
7	20	1	A	1.20			REC: 1009H COPIER		
9	20	1	B		1.26		REC: 1009H, 1009J, 1009K		
11	20	1	C			1.26	REC: 1009L, 1009M, 1009N		
13	20	1	A	1.44			REC: 1009F, 1009E, 1009D		
15	20	1	B		1.44		REC: 1009, 1009D		
17	20	1	C			1.26	REC: 1009C		
19	20	1	A	1.26			REC: 1009B		
21	20	1	B		1.44		REC: 1009A		
23	20	1	C			1.00	REC: 1009L REFRIG		
25	20	1	A	0.18			REC: 1009I		
27	20	1	B		0.50		1014 AUTO DOOR		
29	20	1	C			0.00	SPARE		
31	20	1	A	0.00			SPARE		
33	20	1	B		0.00		SPARE		
35	20	1	C			0.00	SPARE		
37	20	1	A	0.00			SPARE		
39	20	1	B		0.00		SPARE		
41	20	1	C			0.00	SPARE		
43	20	1	A	0.00			SPARE		
45	20	1	B		0.00		SPARE		
47	20	1	C			0.00	SPARE		
49	20	1	A	0.00			SPARE		
51	20	1	B		0.00		SPARE		
53	20	1	C			0.00	SPARE		
55	20	1	A	0.00			SPARE		
57	20	1	B		0.00		SPARE		
59	20	1	C			0.00	SPARE		
61	20	1	A	0.00			SPARE		
63	20	1	B		0.00		SPARE		
65	20	1	C			0.00	SPARE		
67	20	1	A	0.00			SPARE		
69	20	1	B		0.00		SPARE		
71	20	1	C			0.00	SPARE		
SUBTOTAL				4.98	6.08	4.78			