



The Park Danforth
 777 Stevens Ave, Portland, ME, 04103

NO.	DESCRIPTION	DATE
1	Addendum No 2	2015-06-25

CONTENT: SCHEDULES	
DRAWN BY:	DRDLLW
PROJECT NO:	12-056-00
DATE:	6/9/2015
REVISED:	
SCALE:	NO SCALE
E6.4	
Project Phase 100% CONSTRUCTION DRAWINGS	
COPYRIGHT © 2014 BY LAVALLE BRENSINGER PROFESSIONAL ASSOCIATION. ALL RIGHTS RESERVED. NO REPRODUCTION WITHOUT PERMISSION.	

PANEL SCHEDULE - 4N1						
VOLTAGE: 208/120V				MLO: 100A		AIC: 10KA
3-PHASE, 4-WIRE				MCB:		
CIRCUIT BREAKER			CIRCUIT LOAD (KVA) CONNECTED			BRANCH CIRCUIT DESCRIPTION
CKT NO	BRKR SIZE	NO OF POLES	A	B	C	
1	20	1	A	0.00		SPARE
3	20	1	B		0.00	SPARE
5	20	1	C			0.00
7	20	1	A	0.00		SPARE
9	20	1	B		0.00	SPARE
11	20	1	C			0.00
13	20	1	A	0.00		SPARE
15	20	1	B		0.00	SPARE
17	20	1	C			0.00
19	20	1	A	0.00		SPARE
21	20	1	B		0.00	SPARE
23	20	1	C			0.00
SUBTOTAL						
2	20	1	A	0.00		REC: 4000, 4001, 4003, ST-A,
4	20	1	B		0.00	REC: 4003, 4011, 4012, ST-B,
6	20	1	C			REC: 4002, 4005, 4006, 4007,
8	20	1	A	0.00		4008, 4009, 4009B, 4010
10	20	1	B		0.00	REC: 4004
12	20	1	C			LTG: 4004, 4006, 4007, 4002,
14	20	1	A	0.00		4008, 4009A, 4009B, 4010
16	20	1	B		0.00	AUTO DOOR
18	20	1	C			SPARE
20	20	1	A	0.00		SPARE
22	20	1	B		0.00	SPARE
24	20	1	C			0.00
SUBTOTAL						
2	20	1	A	0.00		SPARE
4	20	1	B		0.00	SPARE
6	20	1	C			0.00
8	20	1	A	0.00		SPARE
10	20	1	B		0.00	SPARE
12	20	1	C			0.00
14	20	1	A	0.00		SPARE
16	20	1	B		0.00	SPARE
18	20	1	C			0.00
20	20	1	A	0.00		SPARE
22	20	1	B		0.00	SPARE
24	20	1	C			0.00
SUBTOTAL						

PANEL SCHEDULE - DP4						
VOLTAGE: 208/120V				MLO: 600A		AIC: 22KA
3-PHASE, 4-WIRE				MCB:		
CIRCUIT BREAKER			CIRCUIT LOAD (KVA) CONNECTED			BRANCH CIRCUIT DESCRIPTION
CKT NO	BRKR SIZE	NO OF POLES	A	B	C	
1	20	1	A	0.00		2000 MECH CONTROL
3	20	1	B		1.50	2008A TEL REC
5	20	1	C			1.00
7	20	1	A	1.00		2011 MECH CONTROL
9	20	1	B		1.00	2011 MECH CONTROL
11	20	1	C			0.00
13	20	1	A	0.00		SPARE
15	20	1	B		0.00	SPARE
17	20	1	C			0.00
19	20	1	A	0.00		SPARE
21	20	1	B		0.00	SPARE
23	20	1	C			0.00
25	20	1	A	0.00		SPARE
27	20	1	B		0.00	SPARE
29	20	1	C			0.00
SUBTOTAL						
2	20	1	A	1.00		3000 MECH CONTROL
4	20	1	B		1.00	3000 MECH CONTROL
6	20	1	C			1.50
8	20	1	A	1.00		3008 TEL REC
10	20	1	B		1.00	3011 MECH CONTROL
12	20	1	C			0.00
14	20	1	A	0.00		SPARE
16	20	1	B		0.00	SPARE
18	20	1	C			0.00
20	20	1	A	0.00		SPARE
22	20	1	B		0.00	SPARE
24	20	1	C			0.00
26	20	1	A	0.00		SPARE
28	20	1	B		0.00	SPARE
30	20	1	C			0.00
SUBTOTAL						
2	100	2	A	9.29		APT 1406
4	100	2	B		6.72	
6	100	2	C			9.29
8	100	2	A	6.72		APT 1407
10	100	2	B		9.29	
12	100	2	C			6.72
14	100	2	A	9.29		APT 1408
16	100	2	B		6.72	
18	100	2	C			9.29
20	100	2	A	7.81		APT 1410
22	100	2	B		9.29	
24	100	2	C			7.81
26	100	2	A	9.56		APT 1411
28	100	2	B		9.19	
30	20	1	C			0.00
32	20	1	A	0.00		SPARE
34	20	1	B		0.00	SPARE
36	20	1	C			0.00
38	20	1	A	0.00		SPARE
40	20	1	B		0.00	SPARE
42	20	1	C			0.00
SUBTOTAL						

PANEL SCHEDULE - 3S1						
VOLTAGE: 208/120V				MLO: 100A		AIC: 10KA
3-PHASE, 4-WIRE				MCB:		
CIRCUIT BREAKER			CIRCUIT LOAD (KVA) CONNECTED			BRANCH CIRCUIT DESCRIPTION
CKT NO	BRKR SIZE	NO OF POLES	A	B	C	
1	20	1	A	1.00		2000 MECH CONTROL
3	20	1	B		1.50	2008A TEL REC
5	20	1	C			1.00
7	20	1	A	1.00		2011 MECH CONTROL
9	20	1	B		1.00	2011 MECH CONTROL
11	20	1	C			0.00
13	20	1	A	0.00		SPARE
15	20	1	B		0.00	SPARE
17	20	1	C			0.00
19	20	1	A	0.00		SPARE
21	20	1	B		0.00	SPARE
23	20	1	C			0.00
25	20	1	A	0.00		SPARE
27	20	1	B		0.00	SPARE
29	20	1	C			0.00
SUBTOTAL						
2	20	1	A	1.00		3000 MECH CONTROL
4	20	1	B		1.00	3000 MECH CONTROL
6	20	1	C			1.50
8	20	1	A	1.00		3008 TEL REC
10	20	1	B		1.00	3011 MECH CONTROL
12	20	1	C			0.00
14	20	1	A	0.00		SPARE
16	20	1	B		0.00	SPARE
18	20	1	C			0.00
20	20	1	A	0.00		SPARE
22	20	1	B		0.00	SPARE
24	20	1	C			0.00
26	20	1	A	0.00		SPARE
28	20	1	B		0.00	SPARE
30	20	1	C			0.00
SUBTOTAL						

PANEL SCHEDULE - 3N1						
VOLTAGE: 208/120V				MLO: 225A		AIC: 22KA
3-PHASE, 4-WIRE				MCB:		
CIRCUIT BREAKER			CIRCUIT LOAD (KVA) CONNECTED			BRANCH CIRCUIT DESCRIPTION
CKT NO	BRKR SIZE	NO OF POLES	A	B	C	
1	20	1	A	1.18		RM 3005 WASHER
3	20	1	B		1.18	RM 3005 WASHER
5	20	1	C			1.18
7	20	1	A	1.50		RM 3005 LAUNDRY CKT
9	20	1	B		1.44	REC: 3000, 3001, 3004, ST-A,
11	20	1	C			1.26
13	20	1	A	1.08		REC: 3003, 3011, 3012
15	20	1	B		0.30	REC: 3002, 3003, 3007, 3006,
17	20	1	C			3009, 3010
19	20	1	A	0.00		LTG: 3005, 3002, 3007, 3008,
21	20	1	B		0.50	3009, 3010
23	20	1	C			2010 AUTO DOOR
25	20	1	A	0.00		SPARE
27	20	1	B		0.00	SPARE
29	20	1	C			0.00
31	20	1	A	0.00		SPARE
33	20	1	B		0.00	SPARE
35	20	1	C			0.00
37	20	1	A	0.00		SPARE
39	20	1	B		0.00	SPARE
41	20	1	C			0.00
SUBTOTAL						
2	30	2	A	3.43		RM 3005 DRYER
4	30	2	B		3.43	
6	30	2	C			3.43
8	30	2	A	3.43		RM 3005 DRYER
10	30	2	B		3.43	
12	30	2	C			3.43
14	20	1	A	0.00		SPARE
16	20	1	B		0.00	SPARE
18	20	1	C			0.00
20	20	1	A	0.00		SPARE
22	20	1	B		0.00	SPARE
24	20	1	C			0.00
26	20	1	A	0.00		SPARE
28	20	1	B		0.00	SPARE
30	20	1	C			0.00
32	20	1	A	0.00		SPARE
34	20	1	B		0.00	SPARE
36	20	1	C			0.00
38	20	1	A	0.00		SPARE
40	20	1	B		0.00	SPARE
42	20	1	C			0.00
SUBTOTAL						

PANEL SCHEDULE - MS1						
VOLTAGE: 208/120V				MLO: 100A		AIC: 10KA
3-PHASE, 4-WIRE				MCB:		
CIRCUIT BREAKER			CIRCUIT LOAD (KVA) CONNECTED			BRANCH CIRCUIT DESCRIPTION
CKT NO	BRKR SIZE	NO OF POLES	A	B	C	
1	20	1	A	1.00		128 MECH CONTROL
3	20	1	B		1.00	135A MECH CONTROL
5	20	1	C			1.00
7	20	1	A	1.00		126 MECH CONTROL
9	20	1	B		1.00	125 MECH CONTROL
11	20	1	C			1.00
13	20	1	A	1.70		123A MECH CONTROL
15	20	2	B		1.70	122C MECH CONTROL
17	20	1	C			0.00
19	20	1	A	0.00		SPARE
21	20	1	B		0.00	SPARE
23	20	1	C			0.00
25	20	1	A	0.00		SPARE
27	20	1	B		0.00	SPARE
29	20	1	C			0.00
SUBTOTAL						
2	20	1	A	0.60		CUH-1, (EX) CUH IN STAIR
4	20	1	B		0.00	SPARE
6	20	1	C			0.00
8	20	1	A	0.00		SPARE
10	20	1	B		0.00	SPARE
12	20	1	C			0.00
14	20	1	A	0.00		SPARE
16	20	1	B		0.00	SPARE
18	20	1	C			0.00
20	20	1	A	0.00		SPARE
22	20	1	B		0.00	SPARE
24	20	1	C			0.00
26	20	1	A	0.00		SPARE
28	20	1	B		0.00	SPARE
30	20	1	C			0.00
SUBTOTAL						

PANEL SCHEDULE - 5S1						
VOLTAGE: 208/120V				MLO: 100A		AIC: 10KA
3-PHASE, 4-WIRE				MCB:		
CIRCUIT BREAKER			CIRCUIT LOAD (KVA) CONNECTED			BRANCH CIRCUIT DESCRIPTION
CKT						