

**LEVEL 3 FRAMING PLAN**  
 1/8"=1'-0"


- NOTES:
- INDICATES SPAN DIRECTION OF 5 1/2" NORMAL WEIGHT CONC SLAB ON 3VLI 18GA GALV COMPOSITE DECK W/6x6-W1.4xW1.4 W.W.F. (2 1/2" CONC FILL OVER 3" DECK, 5 1/2" TOTAL, 3 SPAN MIN).
  - TOP OF SLAB EL 190'-5 5/8".
  - TOP OF STEEL EL 190'-0 1/8" U.N.O. BY (2x'x')
  - [10], [12], ETC. INDICATES NUMBER OF 3/4"x4 1/2" HEADED STUDS SPACED UNIFORMLY ALONG SPAN OR BETWEEN CONCENTRATED LOADS U.N.O.
  - INDICATES MOMENT CONNECTION. SEE MOMENT CONNECTION DETAILS.
  - BF-X INDICATES VERTICAL BRACING. SEE BRACED FRAME ELEVATIONS DWG S4.2 & S4.3.
  - BEAMS ARE LOCATED AT EQUAL SPACES BETWEEN COL LINES UNLESS NOTED OTHERWISE.
  - FOR COMPOSITE BEAM END REACTIONS, SEE SIMPLE BEAM CONNECTION SCHEDULE DWG S3.1.
  - E.O.S. INDICATES EDGE OF SLAB. E.O.S. 0'-7" U.N.O.

Owner

**The Park Danforth**

77 Stevens Ave, Portland, ME 04103

NO.	DESCRIPTION	DATE
1	GENERAL REVISIONS	06-10-15



CONTENT: LEVEL 3-NEW BUILDING-FRAMING PLAN	
DRAWN BY:	A.P.P.
PROJECT NO:	3422
DATE:	05/27/15
REVISED:	
SCALE:	As indicated
<b>S1.3C</b>	
Project Phase Package 2 - Foundations and Structural Steel	
COPYRIGHT © 2014 BY LAVALLEEBRENSINGER PROFESSIONAL ASSOCIATION. ALL RIGHTS RESERVED. NO REPRODUCTION WITHOUT PERMISSION.	