

LEVEL 5 FRAMING PLAN
1/8"=1'-0"

NOTES:


- INDICATES SPAN DIRECTION OF 5 1/2" NORMAL WEIGHT CONC SLAB ON 3VLI 18GA GALV COMPOSITE DECK W/6x6-W14xW14 W.W.F. (2 1/2" CONC FILL OVER 3" DECK, 5 1/2" TOTAL, 3 SPAN MIN).
- 18GA GALV COMPOSITE DECK (TYP. U.N.O.) BOT R.A. EL. 171'-0"
- TOP OF SLAB EL. 171'-5 5/8" U.N.O.
- TOP OF STEEL EL. 171'-0 1/8" U.N.O. BY (EX-'X')
- [10], [12], ETC. INDICATES NUMBER OF 3/4"x9/16" 1/2" HEADED STUDS SPACED UNIFORMLY ALONG SPAN OR BETWEEN CONCENTRATED LOADS U.N.O.
- INDICATES MOMENT CONNECTION. SEE MOMENT CONNECTION DETAILS.
- BF-X INDICATES VERTICAL BRACING. SEE BRACED FRAME ELEVATIONS DWG S4.2 & S4.3. BEAMS ARE LOCATED AT EQUAL SPACES BETWEEN COL LINES UNLESS NOTED OTHERWISE.
- FOR COMPOSITE BEAM END REACTIONS, SEE SIMPLE BEAM CONNECTION SCHEDULE DWG S3.1.
- E.O.S. INDICATES EDGE OF SLAB. E.O.S. 0'-7" U.N.O.

Owner

The Park Danforth

77 Stevens Ave, Portland, ME 04103

NO.	DESCRIPTION	DATE
1	ADDENDUM #1	06-10-15



CONTENT: LEVEL 5-NEW BUILDING-FRAMING PLAN
DRAWN BY: A.P.P.
PROJECT NO: 3422
DATE: 05/27/15
REVISED: 10/16/15
SCALE: As indicated

S1.5C

Project Phase
CONFORMANCE SET
COPYRIGHT © 2014 BY LAVALLEE BRENSINGER PROFESSIONAL ASSOCIATION. ALL RIGHTS RESERVED.
NO REPRODUCTION WITHOUT PERMISSION.