

POWERPRODUCTS  
107 AUDOBON ROAD #10  
WAKEFIELD, MA 01880

CUSTOMER: Pack D. D'Arbuth UNIT LOCATION: 77 Stevens Av  
2 has 100% load Tonkland, me 01103

REFERENCE #	GENERATOR SET TEST REPORT										SHOP TEST				FIELD TEST			
	0	15	30	45	60	75	90	105	120	135	150	165	180	195	210	225	240	
TIME IN MINUTES	0	208	208	208	208	208	208	208	208	208	208	208	208	208	208	208	208	
AC VOLT	209	209	209	209	209	209	209	209	209	209	209	209	209	209	209	209	209	
AC AMPERAGE	716	716	716	716	716	716	716	716	716	716	716	716	716	716	716	716	716	
FREQUENCY	60.1	60.1	60.1	60.1	60.1	60.1	60.1	60.1	60.1	60.1	60.1	60.1	60.1	60.1	60.1	60.1	60.1	
CALCULATED KILOWATTS	258	258	258	258	258	258	258	258	258	258	258	258	258	258	258	258	258	
LUBE OIL PRESSURE PSI	99%	99	99	99	99	99	99	99	99	99	99	99	99	99	99	99	99	
LUBE OIL TEMP °F	95	85	85	83	83	82	80	78	78	78	78	78	78	78	78	78	78	
COOLANT TEMP °F	141	163	165	165	165	167	167	167	167	167	167	167	167	167	167	167	167	
FUEL PRESSURE PSI																		
FUEL LEVEL																		
AMBIENT TEMP. °F	1100	1115	1130	1145	1200	1218	1230	1240	1240	1240	1240	1240	1240	1240	1240	1240	1240	

ENGINE MAKE: Dezima ENGINE MODEL D146L ENGINE SERIAL# EEZ06501598 RATING: 260  
 GEN MAKE Kohler /HOURS  
 GEN MODEL 250 REZXB GEN SPEC Gm78690-GA1 GEN SERIAL# SGM3267J4 KVA: 325  
 CREDIT CARD # HZ: 60 PHASE: 3Ø  
 T/SWITCH MODEL # T/SWITCH SPEC# WIRE: 12  
 T/SWITCH SERIAL # RPM'S: 1800  
 VOLT: 120/208  
 SERVICE RO # FL AMPS AT UNITY PF: 902  
 FL AMPS AT 0.8PF: 721.6

TECHNICAN NAME Daryl Dyer (Print) CUSTOMER NAME \_\_\_\_\_ DATE 9-13-16  
 TECHNICAN SIGNATURE \_\_\_\_\_ CUSTOMER SIGNATURE \_\_\_\_\_ DATE 9-13-16