

Project:	Park Danforth
Location:	Portland, ME
Becker Job No:	3422

OBSERVATION REPORT

Cast in Place Concrete

Date:	01-05-16 & 01-06-16
Time:	01-05: 8:00 AM 01-06: 9:00 AM
Temp:	01-05: 8° F 01-06: 18° F
Weather:	01-05: Sunny/Clear 01-06: Sunny/Clear

Observation Location:

Footing reinforcement A1-A1.8, A1-B.9(1.1), B.9(1.1)-B.9(1.5).
Elevator A footing and wall reinforcement.

	Satisfactory	Un-Satisfactory	Not Completed	Not Applicable	Comments
Reinforcement Size	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Quantity	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Vertical footing dowels from B.3(1.1)-B.9(1.5) and Elevator A vertical reinforcement for masonry walls had not yet been installed at the time of the visit.
Condition	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Placement	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Embed/Anchors	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Lap Splices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Hot Weather	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Cold Weather	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Bond Beams	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Additional Items	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Additional Items	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Notes:

I was on site per contractor request to discuss miscellaneous questions and observe concrete footing/wall reinforcement for general conformance with the contract documents.

Chris from Giles stated the revised pier dimensions for B.9(1.1) from RFI-0065 would be incorporated during wall construction.

I discussed RFI-0063 with Andrew Pires from PC. Please see below for dimensional clarification for the connector wall off of pier B.9(1.5).

Signed: Alexander R. Wheelock, E.I.

