

Project:	Park Danforth				
Location:	Portland, ME				
Becker Job No:	3422				

<b>OBSERVATION REPORT</b>
Cast in Place Concrete

Date:	04-22-16
Time:	3:00 PM
Temp:	64° F
Weather:	Partly Cloudy

## **Observation Location:**

Pre-slab placement observation: Level 5 Slab on metal deck - West wing

	Satisfactory	Un-Satisfactory	Not Completed	Not Applicable	Comments
Reinforcement Size	$\boxtimes$				
Quantity	$\boxtimes$				
Condition					
Placement					Shift slab rebar to be over beam web penetrations at beams around the 5th floor HVAC floor opening. Provide W.W.F. around trash shoot.
Embed/Anchors	$\boxtimes$				
Lap Splices					
Hot Weather				$\boxtimes$	
Cold Weather				$\boxtimes$	
Bond Beams				$\boxtimes$	
Additional Items					
Additional Items					

## Notes:

I notified Andrew/Kemp from PC of rebar locations to be relocated over steel beams with web penetrations. See attached for comments.

Signed: Alexander R. Wheelock, E.I.







