

<b>Project:</b>	Park Danforth
<b>Location:</b>	Portland, ME
<b>Becker Job No:</b>	3422

**OBSERVATION REPORT**

Cast in Place Concrete

<b>Date:</b>	12-23-15
<b>Time:</b>	8:15 AM
<b>Temp:</b>	35° F - 40° F
<b>Weather:</b>	Overcast

**Observation Location:**

Vertical wall reinforcement, shear keys, and anchor rods from A2.5 - A4.5  
 Interior footing B4  
 Elevator B wall reinforcement  
 Garage entry wall from F11-G11

	Satisfactory	Un-Satisfactory	Not Completed	Not Applicable	Comments
Reinforcement Size	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Quantity	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Condition	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Placement	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Elevator and garage entry slab/masonry dowels were not installed at the time of the visit. BSE made the recommendation to Giles & PC to tie the dowels instead of wet setting them in the walls.
Embed/Anchors	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Lap Splices	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Hot Weather	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Cold Weather	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Bond Beams	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Additional Items	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Additional Items	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

**Notes:**

I was on site per contractor request to discuss miscellaneous questions and observe concrete footing/wall reinforcement for general conformance with the contract documents.

**Signed:** Alexander Wheelock, E.I.