

**Client:** S.W. Cole Engineering, Inc.

**Report:** 003

**Project:** Park Danforth Renovations and Additions

**SWCE Project #:** 14-0065.2

**Date:** February 22, 2016

**Subject:** Structural Steel Site Inspection

We visited the site on this date as requested to continue structural steel inspections on the New Building Area C portion of the Park Danforth Renovations and Additions project located at 777 Stevens Ave. in Portland, ME. Upon arrival we met with the project superintendent for PC Construction. Inspected at this time was the Level 1 framing. Our actions and observations were as follows:

- Layout, welding and fastening of the composite deck was inspected from line 8 to 11.
- Layout and welding of the shear studs was inspected from line 7 to 11.
- The two missing bolts on the first floor framing at C/4.5 noted in our 2/16 report were added and properly tightened.

All inspections performed above appeared acceptable in accordance to AWS, AISC, RCSC and contract documents.

The project superintendent as well as the erector foreman was notified of our findings.

**Inspector;** Michael Bump  
CWI#07091231