

Client: S.W. Cole Engineering, Inc.

Project: Park Danforth Renovations and Additions

SWCE Project #: 14-065.2

Date: July 26, 2016

Subject: Structural Steel Site Inspection

Report: 016

We visited the site on this date as requested to continue structural steel inspections on the New Building Area C portion of the Park Danforth Renovations and Additions project located at 777 Stevens Ave. in Portland, ME. Upon arrival we met with the project superintendent for PC Construction. Our actions and observations were as follows:

- Welding of the radius HSS lintel supports to the columns between lines 5.1 and 6.5 was inspected at all elevations from Level 2 to the Roof.
- Welding of the galvanized lintels to the HSS supports at all elevations between Level 2 to the Roof was inspected between lines 5.1 and 6.5.
- Welding of all galvanized lintels on the east elevation of the East wing was inspected.

All inspections performed above appeared acceptable in accordance to AWS, AISC and contract documents.

The project superintendent and the erector foreman were notified of our findings.

Inspector; Michael Bump
CWI#07091231