

Client: S.W. Cole Engineering, Inc.

Project: Park Danforth Renovations and Additions

SWCE Project #: 14-0065.2

Date: September 6, 2016

Subject: Structural Steel Site Inspection

Report: 018

We visited the site on this date as requested to continue structural steel inspections on the New Building Area C portion of the Park Danforth Renovations and Additions project located at 777 Stevens Ave. in Portland, ME. Upon arrival we met with the project superintendent for PC Construction. Our actions and observations were as follows:

- Two galvanized lintels on the west elevation of the West Wing between lines 2 and 2.5 had to be removed and shimmed. Shim plates were added and welded per RFI #0240 and all welds were visually inspected.

All inspections performed above appeared acceptable in accordance to AWS, AISC and contract documents.

The project superintendent as well as the erector foreman was notified of our findings.

Inspector; Michael Bump
CWI#07091231