

**Client:** S.W. Cole Engineering, Inc.

**Report:** 021

**Project:** Park Danforth Renovations and Additions

**SWCE Project #:** 14-065.2

**Date:** October 24, 2016

**Subject:** Structural Steel Site Inspection

We visited the site on this date as requested to continue structural steel inspections on the Area B Connector & Auditorium Roof framing portion of the Park Danforth Renovations and Additions project located at 777 Stevens Ave. in Portland, ME. Upon arrival we met with the project superintendent for PC Construction. Our actions and observations were as follows:

- Welding of the relieving angles was inspected.
- Roof hatch opening framing was added in the Auditorium between lines M and N. Visual inspections of the welds were performed.
- An HSS header was added at the existing Main St. Sunroom at the 1<sup>st</sup> floor per 1/S1.1A. Anchoring and welding of the bent plate were inspected.

All inspections performed above appeared acceptable in accordance to AWS, AISC, RCSC and contract documents.

The project superintendent was notified of our findings.

**Inspector;** Michael Bump  
CWI#07091231