

Concrete Construction Observation Report

Project Name/Location: The Park Danforth				F	Project No:	14-0065.2
Client/Client's Rep.:	/Client's Rep.: The Park Danforth / Ron Norton				Date:	12-4-15
Concrete Contractor:	NS Giles			5	Sheet:	1 of 1
Placement Location:	Wall: line 11G-H / Footing: line 8 G & F			5	S.W.COLE Rep	D.: AAB
Weather:	Cloudy 43°F			C	On Site: 2:00 to 5:45pm	
Pre Placement Observations			In Com	oliance	N/O	Comments
Bar size and location (diameter, length, bend and coverage)			Yes 🗌	No 🗌		Inspected by Becker
Splicing (type, overlap)			Yes 🗌	No 🗌		
Stability (wiring, chairs, and spacers)			Yes 🗌	No 🗌		
Reinforcement conditions (cleanliness, temperature etc.)			Yes 🗌	No 🗌		
Embedments and anchor bolts installed			Yes 🗌	No 🗌		
Soil subgrade prepared in accordance with project specifications			Yes 🗌	No 🗌		
Referenced Drawings		Date	Page(s)	Rev.	ASTM	GRADE
					A 615 🗌	40 🗌 50 🗌 60 🗌
					A 616 🗌	75 🗌
					A 617	
					A 706 🗌	А 775 Ероху 🗌
Concrete Placement Observations		In Compl	iance	N/O	Comments	
Required mix used			Yes 🖂	No 🗌		3500-psi design w/ air
Concrete properly conveyed to all areas of placement			Yes 🖂	No 🗌		Pump
Internal vibration / consolidation of concrete			Yes 🖂	No 🗌		Mechanically consolidated
Even layering around openings and embedments		Yes 🖂	No 🗌			
Post placement observations (finishing, curing, etc.)			Yes 🗌	No 🗌		Not onsite
Field Testing of Concrete Performed		Yes 🛛	No 🗌	Loads:	5 Yards: 50	
*Cylinder Set Number:	730-8 & 9	←*refer to associated concrete test report				
Non-Conformance Items Observed (person notified)			Yes 🗌	No 🖂		

Notes:

S.W.COLE was on site to perform concrete testing per request. Concrete was placed in two footings without master set, the wall section was placed with master set. Test results were within spec, 2 sets of test cylinders were made before my departure; one for wall and one for footings.

Attachments: NONE

Reviewed By: RED

The S.W.COLE field representative is on-site at the request of our client to provide construction materials testing and to observe and document construction activities. The contractor has sole responsibility for schedule, site safety, methods, completeness and quality control.