

The Park Danforth

Project Name/Location:

Concrete Construction Observation Report

Project No:

14-0065.2

Client/Client's Rep.:	The Park Danforth / Ron Norton				Date:	12-16-15
Concrete Contractor:	NS Giles			Sheet:	1 of 1	
Placement Location:	Wall: line E/10.5 to E/8			S.W.COLE Rep.:		ep.: J. Rouillard
Weather:	Sunny +/- 45°F				On Site:	1:15 to 3:45pm
Pre Placement Observations	3		In Comp	liance	N/O	Comments
Bar size and location (diameter, length, bend and coverage)			Yes 🗌	No 🗌		Inspected by Becker
Splicing (type, overlap)			Yes 🗌	No 🗌		
Stability (wiring, chairs, and spacers)			Yes 🗌	No 🗌		
Reinforcement conditions (cleanliness, temperature etc.)			Yes 🗌	No 🗌		
Embedments and anchor bolts installed			Yes 🗌	No 🗌		
Soil subgrade prepared in accordance with project specifications			Yes 🗌	No 🗌		
Referenced Drawings		Date	Page(s)	Rev	. ASTM	GRADE
					A 615 🗌	40 🗌 50 🗌 60 🗌
					A 616 🗌	75 🗌
					A 617 □	
					A 706 □	A 775 Epoxy 🗌
Concrete Placement Observations			In Compliance		N/O	Comments
Required mix used				No 🗌		3500-psi design w/ air
Concrete properly conveyed to all areas of placement			Yes 🛛	No 🗌		Pump
Internal vibration / consolidation of concrete			Yes 🛚	No 🗌		Mechanically consolidated
Even layering around openings and embedments			<u> </u>	No 🗌	<u> </u>	
Post placement observations (finishing, curing, etc.)				No 🗌		Not onsite
Field Testing of Concrete Performed				No 🗌	Loads:	5 Yards: 48
*Cylinder Set Number: 730-12			←*refer to associated concrete test report			
Non-Conformance Items Ob Notes:	served (person notified)		Yes	No 🗵		
S.W.COLE was on site to monitor concrete being placed for footings and walls along line C, D, G & H. Concrete was delivered by Auburn Concrete and was a 3500 psi ¾" mix design containing Glenium 7500 (water reducer) and Master Air (Entrainer) added during the batching process. A crew from N.S. Giles formed and placed a total of 47cy of concrete via pump truck. All concrete tested at time of placement was within project specifications. Attachments: None Reviewed By: RED						
Audomients. None			Reviewed By: RED			

The S.W.COLE field representative is on-site at the request of our client to provide construction materials testing and to observe and document construction activities. The contractor has sole responsibility for schedule, site safety, methods, completeness and quality control.