

Report of Field Density

ASTM D6938

Project: **PORTLAND ME - THE PARK DANFORTH - CONSTRUCTION MATERIALS TESTING SERVICES** Project Number: **14-0065.2**

Client: **THE PARK-DANFORTH**

Field Density Test Results

Test #	Test Date	Tech	Test Location	Elev Feet	Test Depth	Lab ID	Dry Density	Moisture Content Percent	Compaction Percent	Required Compaction
36	1/4/2016	JR	E.1 @ 5.1	6'	12"	20240G	112.1	7.9	102.8	95
37	1/4/2016	JR	E.1 @ 6	6'	12"	20240G	109.2	7.3	100.2	95

Laboratory Compaction Test Reference

Lab ID	Date Received	Material Source	Material Type	Method	Max Dry Density PCF	Optimum Moisture Content (%)	Comments
20240G	11/18/2015	On Site Borrow	Granular Borrow	ASTM D-1557 Modified A	109.0	12.3	

Elevation Notes:

ALL ELEVATIONS ARE BELOW TOP OF WALL

Comments:



 Reviewed By