



SEE SHEET 9  
SEE SHEET 9

PLANS PREPARED BY:  
BRIAN BENNETT  
NICET LEVEL 3 CERT. #0759344

THESE PLANS ARE SUBJECT TO MINOR  
DEVIATIONS, DUE TO COORDINATION AND/OR  
FIELD CONDITIONS, NOT AFFECTING SCOPE OF  
WORK OR CODE COMPLIANCE.

SCALE 1/8" = 1'-0"

**Hampshire**  
FIRE PROTECTION

8 NORTH WENTWORTH AVENUE, LEONCONGERRI, NH 03029  
PH: (603) 432-8221 FAX: (603) 434-3194  
WEBSITE: HAMPSHIREFC.COM  
MSS VERMONT CERTIFIED

SCALE 1/8" = 1'-0"

WATER SUPPLY DATA

Static pressure	62	psi
Residual pressure	40	psi
Location	See Site Plan	
Elevation	43	
Date	10-25-14	Time 11:00 AM
Information by	Pauline Waver Dept.	

SPRINKLERS

From This Sheet	131	From This Job See Sheet	1
Symbol	RELIABLE FLOOR SPRINKLER	Description	RELIABLE FLOOR SPRINKLER
1	RELIABLE FLOOR SPRINKLER	DESCRIPTION	RELIABLE FLOOR SPRINKLER
2	RELIABLE FLOOR SPRINKLER	DESCRIPTION	RELIABLE FLOOR SPRINKLER
3	RELIABLE FLOOR SPRINKLER	DESCRIPTION	RELIABLE FLOOR SPRINKLER

Drawing Sheet 7, Level 3

Contract No.	47372CH
Drawn By	Bennett
Scale	1/8" = 1'-0"
Date	2-12-16
Approved by	Pauline Waver Dept.
ME SIGNATURE	

Project: The Park Danforth Expansion & Renovation  
777 Stevens Ave.  
Portland, ME 04103

Contract with:  
PC Construction  
788 Stevens Ave.  
Portland, ME 04103