PLANS PREPARED BY:
BRIAN BENOIT
NICET LEVEL 3 CERT. #075934
THESE PLANS ARE SUBJECT TO MINOR DEVIATIONS, DUE TO COORDINATION AND/OR FIELD CONDITIONS, NOT AFFECTING SCOPE OF WORK OR CODE COMPLIANCE.
SCALE 1/8"=1'-0"

SCALE 1/8"=1'-0"

N

Hampshire
FIRE PROTECTION
8 NORTH WENTWORTH AVENUE LONDONDERRY, NH 03053
PH:(603) 432-8221 FAX: (603) 434-3194
WEBSITE: HAMPSHIREFIRE.COM
MASS LIC# 003841 MAINE LIC# 238
VERMONT CERTIFIED

WATER SUPPLY DATA		
Static pressure	62	psi
Residual pressure	60	psi
Flow	992	gpm
Location	See Site Plan	
Elevation	+9	
Date	10-25-14	Time 10 AM
Information by	Portland Water Dept., Means Dept.	

SPRINKLERS.

Total This Sheet 61 | Total This Job See Sheet 1

Symbol	Description
61	RELIABLE F1FR REC PEND (1/2"Thd 5.6K) CHROME 155° (RA1414)

Drawing Title	Sheet 3, Grouind Level A
Contract No.	4737CNH
Drawn By	Benoit
Scale	1/8" = 1'-0"
Date	2-12-16
Approval By	Portland Fire Dept. ME SFMO

Revisions:	Date:
1	
2	
3	
4	
5	
6	
7	

Project:
The Park Danforth Expansion & Renovation
777 Stevens Ave.
Portland, ME 04103

Contract with:
PC Construction
789 Stevens Ave.
Portland, ME 04103

FIRE PROTECTION ENGINEER STAMP