4TH FLOOR CONTROL ASSY.
- 2" BFPV VA. W/ TAMPER
- 2" CHECK VA.
- PRESSURE GAUGE
- 1¼" X ¼" TEST DRAIN.
26" FIN 4-0 AFF
INSERT @ A/1
STAIR ST-1
NON-COMBUSTIBLE STAIR, NO A.S.
4" DRAIN RISER
4" STANDPIPE
ELEVATOR ELA
225° ELL 11.25° ELL FLEX CPLGS 36.5" BEND
4" STANDPIPE 36.5" BEND 4-0 AFF
STAIR B ST-4
CENTERLINE WTR MEB PEN TRATIONS (SEE TYP DETAIL S1.2C)
GWB 8'-0" A.F.F.
ACT-10 7'-6" A.F.F.
ACT-1 8'-0" A.F.F.
ACT-4 8'-0"
ACT-5 8'-0"
ACT-6 8'-0"
ACT-7 8'-0"
ACT-8 8'-0"
ACT-9 8'-0"
ACT-14 8'-0"
ACT-15 8'-0"
ACT-16 8'-0"
ACT-17 8'-0"
ACT-18 8'-0"
ACT-19 8'-0"
ACT-20 8'-0"
ACT-21 8'-0"
ACT-22 8'-0"
ACT-23 8'-0"
ACT-24 8'-0"
ACT-25 8'-0"
ACT-26 8'-0"
ACT-27 8'-0"
ACT-28 8'-0"
ACT-29 8'-0"
ACT-30 8'-0"
ACT-31 8'-0"
ACT-32 8'-0"
ACT-33 8'-0"