NFPA 13R sprinkler check list

- □ Is this check list applicable? No
- □ What edition of NFPA 13R is the designed to? _____
- □ Building construction type: _____
- □ Will the sprinkler system provide complete or partial coverage of the building? _____
- □ Will covered exterior balconies, decks and ground floor patios be sprinklered? _____
- □ Size of riser assembly: _____
- □ Fire department connection- number of 2 ½" inlets: _____
- □ Electrical supervision will be provided via the fire alarm system per NFPA 101:9.7.2: _____
- □ Is the nearest fire hydrant within 100 ft. of the FDC? _____
- □ The completed *Contractor's Material and Test Certificate for Aboveground Piping* shall be provided at the completion of the job? _____

NFPA 13 sprinkler check list

- □ Is this check list applicable? Yes
- □ What edition of NFPA 13 is the designed to? 2013
- □ Building construction type: 1B
- □ Will the sprinkler system provide complete or partial coverage of the building? Complete
- □ System type (See NFPA 13:3.4): Wet & Dry
- □ NFPA 13 Occupancy Classification (Hazard): Light & Ordy 1
- □ Is the structure high-rise (see NFPA 101:3.3.32.7)? No
- □ Size of riser assembly: 8"
- □ Fire department connection- number of 2 ½" inlets: 4" Storz
- □ Electrical supervision will be provided via the fire alarm system per NFPA 101:9.7.2: Yes
- □ Is the nearest fire hydrant within 100 ft. of the FDC? Yes
- □ The completed *Contractor's Material and Test Certificate for Aboveground Piping* shall be provided at the completion of the job? Yes

NFPA 14 standpipe check list

- □ Is this check list applicable? Yes
- □ What edition of NFPA 14 is the designed to? 2013

Building Inspections Division · 389 Congress Street · Portland, Maine 04101 · (207) 874-8703 · FACSIMILE (207) 874-8716 · TTY (207) 874-8936