


City of Portland, Maine – Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 1108 Forest Avenue		Owner: Lloyd Wolf & Robert Adan		Phone: 773-4988		Permit No: 980440	
Owner Address: P. O. Box 1382 Portland, ME		Lessee/Buyer's Name:		Phone:		BusinessName:	
Contractor Name: Les Wilson & Sons Box 1028, Westbrook, ME		Address:		Phone:			
Past Use:		Proposed Use:		COST OF WORK: \$		PERMIT FEE: \$ 10.00	
				FIRE DEPT. <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied		INSPECTION: Use Group: Type:	
				Signature: <i>[Signature]</i>		Signature: <i>[Signature]</i>	
Proposed Project Description: removal of 550 gal underground tank				PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action: Approved <input type="checkbox"/> Approved with Conditions: <input type="checkbox"/> Denied <input type="checkbox"/>			
Permit Taken By: Judy Laplante		Date Applied For: 4/29/98					



1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

Zoning Approval:
08 - 56.194

Special Zone or Reviews:

Shoreland
 Wetland
 Flood Zone
 Subdivision
 Site Plan maj minor mm

Zoning Appeal

Variance
 Miscellaneous
 Conditional Use
 Interpretation
 Approved
 Denied

Historic Preservation

Not in District or Landmark
 Does Not Require Review
 Requires Review

Action:

Approved
 Approved with Conditions
 Denied

Date: _____

PERMIT ISSUED WITH REQUIREMENTS

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

see pre-app 4/29/98

SIGNATURE OF APPLICANT _____ ADDRESS: _____ DATE: _____ PHONE: _____

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE _____ PHONE: _____

CEO DISTRICT

COMMENTS

10/18/99
Tank removed during
reposed muck

Inspection Record

Type	Date
Foundation: _____	_____
Framing: _____	_____
Plumbing: _____	_____
Final: _____	_____
Other: _____	_____

NOTICE OF INTENT TO ABANDON (REMOVE)
AN UNDERGROUND OIL STORAGE FACILITY

COPY

THIS FORM MUST BE FILED WITH THE D.E.P. AND YOUR LOCAL FIRE DEPARTMENT AT
LEAST 30 DAYS PRIOR TO THE SCHEDULED REMOVAL

PLEASE TYPE OR PRINT IN INK:

Name of Facility Owner: Lloyd Wolf + Robert Adam
Mailing Address: P.O. Box 1382 Telephone #: 773 4988
City: Portland State: ME Zip Code: 04104
Contact Person (name, address & telephone #): Lloyd Wolf

Name of Facility: GO-GO Burger Registration #: _____
Facility Location (town & street): 1108 Forest Ave Portland, Me

1. Identify the tanks at this location which are going to be removed:

Tank #	Tank Age	Tank Size (gallons)	Type of Product Stored
1	N/A	550	# 2 Fuel Oil
2			
3			

2. Directions to this facility (be specific):

Corner of Arbor St, + Forest Ave. tank located on
Arbor St, side,

3. Is or was the tank(s) used to store Class I liquids (e.g., gasoline, jet fuel)? Yes _____ No
IF YES, REMOVAL OF THE TANK(S) MUST BE DONE UNDER THE DIRECTION OF A
CERTIFIED TANK INSTALLER.

Tank Installer's Name: _____ Certification Number: _____ Signature _____
N/A

4. Environmental site assessments are required for all tanks except those used for storing heating oil, not for resale, or for farm or residential motor fuel tanks under 1,100 gallons where the product is used on site. Site Assessor's Name and Address (if applicable):

N/A

5. Name and telephone number of contractor who will do the tank removal:

LES WILSON & SONS INC. 854 4583

6. Expected date of removal (month/day/year): 5/22/98

I hereby provide Notice that I intend to properly abandon the underground oil storage facility as described above.

Date: 4/22/98 Signature of owner or operator: Ronald Wilson

Printed Name and Title: RONALD WILSON / AGENT FOR OWNER

Mail original and yellow copy to DEP; pink copy to fire department; retain gold copy.
RETURN POSTCARD AFTER TANK(S) HAS BEEN REMOVED

PORTLAND FIRE DEPARTMENT

Review Date: 4/30/98 Contractor: Mrs. Wilson Jones

Address: 1108 Forest Ave CBL: _____

Please note marked Conditions of Approval

- * The boiler or furnace shall be protected by enclosing with one hour fire rated construction including fire doors and ceiling or by providing automatic extinguishment and smoke protected enclosure. Sprinkler piping serving not more than six sprinklers may be connected to a domestic water supply system having a capacity sufficient to provide a 0.15 gpm per sq ft of floor throughout the entire area. An indicating shut-off valve shall be installed in an accessible location between the sprinkler and the connection to the domestic water supply. Minimum pipe size shall be 3/4" copper or 1" steel. Maximum coverage area of a residential sprinkler in 144 sq ft per sprinkler.
- * All required fire alarm systems shall have the capacity of zone disconnect via switches or key pad program provided the method is approved by the Fire Prevention Bureau.
- * All remote annunciators shall have a visible trouble indicator along with the fire alarm zone indicators.
- * Any master box connected to the municipal fire alarm system shall have a supervised municipal disconnect switch.
- * All master box locations shall be approved by the Fire Dept. Director of Communications.
- * A master box shall be located so that the center of the box is five feet above finished floor.
- * All master box locations are required to have a Knox box.
- * A fire alarm acceptance report shall be submitted to the Portland Fire Department.
- All underground tank removal(s) and/or installation(s) shall be done in accordance with the Department of Environmental Protection and Regulation (Chapter 691).
- No cutting of tanks on site. Cutting of tanks to be done at an approved disposal site.
- The fire dispatcher must be notified at least 48 hrs in advance of removal or transportation of tanks.
- * All above ground L/P tanks shall be located in accordance with NFPA 58 standards.
- * Any tank located near the path of vehicle movement shall be protected.
- * All piping shall be protected from possible mechanical damage and vandalism.
- * A 4" storz fire department connection is required.
- * Any renovation of sprinkler system over 20 heads must have State Fire Marshall approval.
- * A sprinkler performance test shall be submitted to the P.F.D. after completion of work.
- * State Fire Marshall approval is required for this project.


Lt. Gaylén Mc Dougall
Portland Fire Prevention Bureau