

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND BUILDING PERMIT



**This is to certify that**

V S H REALTY INC

**Located at**

1132 FOREST AVE (Cumberland Farms)

**PERMIT ID:** 2017-01150

**ISSUE DATE:** 08/17/2017

**CBL:** 146 D001001

has permission to **Install non water based fire suppression system NFPA17 under gas pump canopy.** provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

*/s/ David Petruccelli*

**Fire Official**

*/s/ Michael Russell, MS, Director*

**Building Official**

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
THERE IS A PENALTY FOR REMOVING THIS CARD**

*Approved Property Use - Zoning*

*Building Inspections*

*Fire Department*

BUILDING PERMIT INSPECTION PROCEDURES  
Please call 874-8703  
or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

**Check the Status of Permit or Schedule an Inspection at  
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit.**
- **Permits expire in 6 months if the project is not started or ceases for 6 months.**
- **If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.**

## **REQUIRED INSPECTIONS:**

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

<b>City of Portland, Maine - Building or Use Permit</b>		<b>Permit No:</b> 2017-01150	<b>Date Applied For:</b> 07/17/2017	<b>CBL:</b> 146 D001001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
<b>Proposed Use:</b> Same. Gas station and convenience store - Cumberland Farms	<b>Proposed Project Description:</b> Install non water based fire suppression system NFPA17 under gas pump canopy.			
<b>Dept:</b> Fire <b>Status:</b> Approved w/Conditions <b>Reviewer:</b> David Petruccelli <b>Approval Date:</b> 08/17/2017 <b>Note:</b> <b>Ok to Issue:</b> <input checked="" type="checkbox"/>				
<b>Conditions:</b>				
1) System acceptance and commissioning must be coordinated with an installation technician and the Fire Department. Call 874-8400 to schedule. 2) Construction or installation shall comply with City Code Chapter 10. 3) Application requires State Fire Marshal approval. 4) All outstanding code violations shall be corrected prior to final inspection. 5) Any cutting and welding done will require a Hot Work Permit from Fire Department. 6) Shall meet the requirements the most recent NFPA 30 Flammable and Combustible Liquids Code. 7) Shall meet the requirements of 2009 NFPA 1 Fire Code. 8) NFPA 1 Fire Code Per 1.14.4 Review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code. 9) Fire extinguishers are required per NFPA 1 Table 13.6.2. Placement and Size of extinguishers shall follow NFPA 1 table 13.6.8.2.1.1.				