


CITY OF PORTLAND
 FIRE PREVENTION BUREAU
 380 Congress Street, Portland, Maine 04101
 fireprevention@portlandmaine.gov
 (207) 874-8400



NOTICE OF VIOLATION AND ORDER TO CORRECT

August 8, 2017

Responsible Party 1: 1053 FOREST AVENUE LLC 200 RIVERSIDE INDUSTRIAL PKWY PORTLAND, ME 04103		
Location 1045 FOREST AVE (Ginza)	CBL 146 E009001	Inspection Date 7/19/2017
Inspector Daniel Dyer	Inspection Type FP Routine Inspection	Status Failed

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose a date of completion to remedy each violation, a final date of completion, and a date of re-inspection.

You must send this form to the Fire Prevention Bureau no later than 8/30/2017.

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

Violation	Proposed Date of Completion
1-14.14 ILLUMINATION OF EXIT SIGNS; EXIT SIGNS SHALL BE CONTINUOUSLY ILLUMINATED AND USE AN EMERGENCY LIGHTING SOURCE.	8/21/17
FINAL DATE OF COMPLETED VIOLATION(S)	— / — / —
FIRE PREVENTION BUREAU RE-INSPECTION OF COMPLETED VIOLATION(S)	— / — / —

CAPT. JOE [Signature] 17