


OCCUPANT LOADS	
NFPA 101 LIFE SAFETY (2009 ED)	120 (OCC. TABLE)
IBC (2009 ED)	117 (OCC. TABLE)
ACTUAL SEATING COUNT	92
ACTUAL TOTAL	96

NFPA LEGEND		
SYMBOL	DESCRI PTI ON	
$\mathbf{i}$	EXIT LIGHT	
	FI RE EXTI NGUI SHER (ABC TYPE) OR (K)	
	ABC FIRE EXTINGUI SHER IN SEMI -RECESSED CABINET	
Р	FI RE ALARM PULL MANUAL PULL STATI ON	
FACP	FIRE ALARM PANEL/ ANNUNCI ATOR	
	EMERGENCY LIGHT	
X	FIRE ALARM STROBE UNIT	
	FIRE ALARM HORN/STROBE UNIT	
S	SMOKE DETECTOR	
H	HEAT DETECTOR	
	1 HR. RATED PARTITION	
К	KNOX BOX	
$\bigcirc$	"NOT AN EXIT" SIGN	



J:\\_PROJECTS\GHA\\_PROJECTS\Otto Pizza\A'1.dwg, 5/26/2016 8:21:18 AM, DWG To PDF.pc3

LE AREAS (5% MIN.)	
REA	ADA AREA
ING	2.5 (17%)
TI NG	17.5 (13%)