A DOOR JAMB DETAIL 106

SCALE : 3" = 1'-0"

B FIRE DOOR ELEVATION 106

NO SCALE

STANDARD HOLLOW-METAL STEEL DOOR FRAME

SMOKE-CONTROL DOOR ASSEMBLIES: COMPLY WITH NFPA 105 OR UL 1784 CLOSER

OBTAIN STANDARD STEEL DOORS AND FRAMES FROM SINGLE MANUFACTURER

MANUFACTURERS:
AMMELD BUILDING PRODUCTS
CECO DOOR PRODUCTS
CURRIES COMPANY

GROUT: COMPLY WITH ASTM C 476 WITH A SLUMP OF 4 INCHES

FACTORY APPLIED PAINT FINISH

INSTALL STANDARD STEEL FRAMES TO COMPLY WITH SDI 105 AND NFPA 80

STANDARD HOLLOW-METAL STEEL DOOR WITH SIDELIGHT/PANEL (VISION LITE)

COLD-ROLLED SHEET STEEL, COMMERCIAL STEEL, TYPE B

1 ½" LABEL

NORTON DOOR CLOSER, SURFACE TYPE
KICK PLATE – 190S 8" x 2" LDW, US4
ADA THRESHOLD – 412SG, Ano. Alum.
3 HINGES – BB1191 4.5" X 4.5" NRP, 605
GASKET – 726 X 17, CHARCOAL
RIM EXIT DEVICE F19R X L-LS/LK Capri x SHT, 605
SWEEP – 756ASG

NEW FIRE RATED DOOR 106 AT WALK IN COOLER — AS NOTED

C HC. RAMP RAILING DETAIL

NO SCALE

E SECTION THROUGH RAMP

SCALE : 3" = 1'-0"

D SECTION THROUGH RAMP

SCALE : 3" = 1'-0"

F SECTION THRU FOOTING

SCALE :1/2" = 1'-0"

NEW SERVICE RAMP DETAILS — AS NOTED

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 06/01/16

GRANT HAYS ASSOCIATES
ARCHITECTURE & INTERIOR DESIGN
P.O. BOX 6179 FALMOUTH MAINE 041
207.871.5900 www.granthays.com

SEAL

REVISIONS

PROJECT NAME

OTTO'S PIZZA
TENANT FIT-UP
250 DEAD STREET PORTLAND MAINE 04103

SHEET

DOOR DETAILS
RAMP FRAMING DETAILS

DATE 25 MAY 2016
SCALE AS NOTED
DRAWN SAM/MFH
JOB NO. 160516
SHEET A2

COPYRIGHT
REPRODUCTION OR REUSE OF THIS DOCUMENT WITHOUT WRITTEN PERMISSION FROM GRANT HAYS ASSOCIATES IS PROHIBITED