



Portland Fire Department

JB BROWN & SONS
36 DANFORTH STREET P.O. BOX 207
PORTLAND, ME 04101

RE: 150 READ ST
PORTLAND, ME 04103

147 B001001

150 READ ST Page 1 of 2

**NOTICE OF VIOLATION
AND ORDER TO CORRECT**

To Whom it May Concern,

The City of Portland inspected the above-referenced property on 3/27/2018 and found violations of the City of Portland Code of Ordinances, which are listed on the attached page(s). You are hereby ordered to correct these violations by the dates given on the attached.

A reinspection of your property will take place on 8/15/2018 2:00:00PM .

Please contact the Fire Prevention Bureau at 874-8400 if you have any question about your reinspection. If the violations are not corrected at the time of reinspection, you will be charged a \$150 failed reinspection fee.

If you do not correct the attached violations, then this matter may be referred to the City of Portland Corporation Counsel for legal action, including civil penalties and other legal remedies.

Thank you for keeping the City of Portland safe.

Sincerely,

Captain John Brennan
Fire Prevention Bureau
City of Portland

NON-COMPLIANCE VIOLATION LIST

NAME	CODE DESCRIPTION	COMMENTS	Deadline
NFPA 101-9.1.2; NFPA 70	All electrical equipment must comply with the National Electric Code.	Close all open spaces in the panel. Note: panel had no open circuits. There were at least 2 open junction boxes that still need covers. Charlie wall middle of space and ceiling above Supervisor remembers company installing some covers. Was going to call back to say they missed some. Also stated that there was no power to the junction boxes	5/28/2018
