


**City of Portland, Maine – Building or Use Permit Application** 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 184 Read St		Owner: J.B. Brown		Phone:		Permit No: <b>970927</b>	
Owner Address:		Lessee/Buyer's Name: Corey Electric		Phone:		Business Name:	
Contractor Name: Portland Pump		Address: P.O. Box 1180 Scarborough, ME 04074		Phone: 883-4317		<div style="border: 2px solid black; padding: 5px; text-align: center;"> <b>PERMIT ISSUED</b>                  Permit Issued:  <b>AUG 27 1997</b>  <b>CITY OF PORTLAND</b> </div>	
Past Use: Office		Proposed Use: Same		COST OF WORK: \$ _____ FIRE DEPT. <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied			
Proposed Project Description:  Remove underground tank				PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action:           Approved <input type="checkbox"/> Approved with Conditions: <input type="checkbox"/> Denied <input type="checkbox"/> Signature: _____ Date: _____		Zone: CBL: 147-B-003 Zoning Approval: <i>[Signature]</i> Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>	
Permit Taken By: Mary Gresik		Date Applied For: 22 August 1997					

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..



**CERTIFICATION**

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

SIGNATURE OF APPLICANT <i>[Signature]</i>		ADDRESS:		DATE: 22 August 1997		PHONE:	
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE						PHONE:	
White-Permit Desk    Green-Assessor's    Canary-D.P.W.    Pink-Public File    Ivory Card-Inspector						CEO DISTRICT <span style="border: 1px solid black; padding: 5px; display: inline-block;">6</span>	

**City of Portland, Maine – Building or Use Permit Application** 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 184 Read St		Owner: J.B. Brown		Phone:		Permit No: <b>970927</b> <div style="border: 2px solid black; padding: 5px; margin: 5px;">                     PERMIT ISSUED                      AUG 27 1997                      CITY OF PORTLAND                 </div> Permit Issued: AUG 27 1997 CITY OF PORTLAND		
Owner Address:		Lessee/Buyer's Name: Corey Electric		Phone:			Business Name:	
Contractor Name: Portland Pump		Address: P.O. Box 1180 Scarborough, ME		Phone: 04074 883-4317				
Past Use: Office		Proposed Use: Same		COST OF WORK: \$			PERMIT FEE: \$ 10.00	
				FIRE DEPT. <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied		INSPECTION: Use Group: Type:		
Proposed Project Description:  Remove underground tank				Signature: <i>[Signature]</i>		Signature: <i>[Signature]</i>		
				PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)		Zone: CBL: 147-B-003		
				Action: Approved <input type="checkbox"/>		Zoning Approval: <i>[Signature]</i> 8/26/97		
				Approved with Conditions: <input type="checkbox"/>		Special Zone or Reviews:		
				Denied <input type="checkbox"/>		<input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>		
Permit Taken By: Mary Gresik		Date Applied For: 22 August 1997						

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..



**CERTIFICATION**

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

*[Signature]*  
 SIGNATURE OF APPLICANT      Don Cyr      ADDRESS:      DATE: 22 August 1997      PHONE:

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE      PHONE:

White-Permit Desk    Green-Assessor's    Canary-D.P.W.    Pink-Public File    Ivory Card-Inspector

- Zoning Appeal**
- Variance
  - Miscellaneous
  - Conditional Use
  - Interpretation
  - Approved
  - Denied

- Historic Preservation**
- Not in District or Landmark
  - Does Not Require Review
  - Requires Review

- Action:**
- Appoved
  - Approved with Conditions
  - Denied

Date: 8/25/97

*[Signature]*

CEO DISTRICT *[Signature]*  
 M. Leary

## FIRE CODE PERMIT REPORT

DATE: 8/24/97 ADDRESS: 184 Reed StPERMIT TO: Portland PumpOWNER/CONTRACTOR: " "APPROVED ✓ DENIED \_\_\_\_\_CONDITIONS OF APPROVAL/DENIAL

1. The boiler or furnace shall be protected by enclosing with one hour fire rated construction including fire doors and ceiling or by providing automatic extinguishment and smoke protected enclosure. Sprinkler piping serving not more than six sprinklers may be connected to a domestic water supply system having a capacity sufficient to provide a 0.15 gpm, per square foot of floor throughout the entire area. An indicating shut-off valve shall be installed in an accessible location between the sprinkler and the connection to the domestic water supply. Minimum pipe size shall be 3/4 inch copper or 1 inch steel. Maximum coverage area of a residential sprinkler is 144 square feet per sprinkler.
2. All required Fire Alarm Systems shall have the capability of "Zone Disconnect" via switches or key pad program provided the method is approved by the Fire Prevention Bureau.
3. All remote annunciators shall have a visible "trouble" indicator along with the Fire Alarm "Zone" indicators.
4. Any Master Box connected to the Municipal Fire Alarm System shall have a supervised Municipal Disconnect Switch.
5. All Master Box locations shall be approved by the Fire Department Director or Communications. A Master Box shall be located so that the center of the box is five feet above finished floor.
6. All Master Box locations are required to have a locked box (knoxbox).
7. A fire alarm acceptance report shall be submitted to the Portland Fire Department.
8. All underground tank removal(s) and/or installation(s) shall be done in accordance with the Department of Environmental Regulations (Chapter 691).
9. No cutting of tanks on site. Cutting of tanks is to be done at an approved tank disposal site.
10. Fire Dispatcher must be at least 48 hours in advance of removal and/or transportation of tanks.
11. All above ground L/P storage tanks shall be located in accordance with NFPA 53 Standards.
12. Any tank located near the path of vehicle movement shall be protected with appropriate permanent barricades.

Maine Department of Environmental Protection  
Bureau of Remediation and Waste Management  
17 State House Station  
Augusta, Maine 04333-0017  
Attention: Tank Removal Notice  
Telephone: (207) 287-2651

Expires after 6 (six) months if the  
Department does not receive notice that  
removal was completed.

**NOTICE OF INTENT TO ABANDON (REMOVE)  
AN UNDERGROUND OIL STORAGE FACILITY**

147-B-003

**THIS FORM MUST BE FILED WITH THE D.E.P. AND YOUR LOCAL FIRE DEPARTMENT AT  
LEAST 30 DAYS PRIOR TO THE SCHEDULED REMOVAL**

PLEASE TYPE OR PRINT IN INK:

Name of Facility Owner: COREY ELECTRIC J. B. Brown  
Mailing Address: 184 REED ST. Telephone #: 775-1380  
City: PORTLAND State: ME Zip Code: 04103  
Contact Person (name, address & telephone #): \_\_\_\_\_

STEVE COREY SAME AS ABOVE  
Name of Facility: SAME AS ABOVE Registration #: 3050  
Facility Location (town & street): \_\_\_\_\_

1. Identify the tanks at this location which are going to be removed:

Tank #	Tank Age	Tank Size (gallons)	Type of Product Stored
1	?	1000	<del>HEATING OIL</del> MOTOR FUEL
2			
3			

2. Directions to this facility (be specific):

3. Is or was the tank(s) used to store Class I liquids (e.g., gasoline, jet fuel)? Yes  No   
**IF YES, REMOVAL OF THE TANK(S) MUST BE DONE UNDER THE DIRECTION OF A  
CERTIFIED TANK INSTALLER.**

Tank Installer's Name: David W. Cox Field Certification Number: 092 Signature: [Signature]

4. Environmental site assessments are required for all tanks except those used for storing heating oil, not for resale, or for farm or residential motor fuel tanks under 1,100 gallons where the product is used on site. Site Assessor's Name and Address (if applicable):

ACADIA ENVIRONMENTAL 780-8826

5. Name and telephone number of contractor who will do the tank removal:

Portland Pump Co 1-800-640-7867

6. Expected date of removal (month/day/year): 8/9/97

I hereby provide Notice that I intend to properly abandon the underground oil storage facility as described above.

Date: 7/9/97 Signature: [Signature] (AGENT)

Printed Name and Title: David W. Cox Field G.M.

**Mail original and yellow copy to DEP; pink copy to fire department; retain gold copy.  
RETURN POSTCARD AFTER TANK(S) HAS BEEN REMOVED**


West

R  
G  
R  
D

Multi Business  
Building

Office  
Corey  
Electric

TANK



Garage

S  
T

Parking

EAST

