

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND BUILDING PERMIT



**This is to certify that**

CONGDON F GILBERT III ETALS

**Located at**

52 Canco Rd

**PERMIT ID:** 2015-00324

**ISSUE DATE:** 02/25/2015

**CBL:** 147 C001001

has permission to **Warehouse roof structure was damage from extreme snow load, this project is for temporary shoring. A separate application will be submitted for the repairs.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

*/s/ Jeanie Bourke*

**Fire Official**

*/s/ Jeanie Bourke*

**Building Official**

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
THERE IS A PENALTY FOR REMOVING THIS CARD**

***Approved Property Use - Zoning***

Warehouse Storage

***Building Inspections***

**Use Group:** S-2      **Type:** 5B

Storage - Low Hazard  
NFPA 13 Sprinkler System

Roof

MUBEC/IBC 2009

***Fire Department***

BUILDING PERMIT INSPECTION PROCEDURES  
Please call 874-8703 (ONLY)  
or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

**Check the Status or Schedule an Inspection On-Line at  
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

## **REQUIRED INSPECTIONS:**

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

<b>City of Portland, Maine - Building or Use Permit</b>		<b>Permit No:</b> 2015-00324	<b>Date Applied For:</b> 02/25/2015	<b>CBL:</b> 147 C001001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
<b>Proposed Use:</b> Warehouse	<b>Proposed Project Description:</b> Warehouse roof structure was damage from extreme snow load, this project is for temporary shoring. A separate application will be submitted for the repairs.			
<b>Dept:</b> Zoning <b>Status:</b> Approved w/Conditions <b>Reviewer:</b> Ann Machado <b>Approval Date:</b> 02/25/2015 <b>Note:</b> <b>Ok to Issue:</b> <input checked="" type="checkbox"/> <b>Conditions:</b> 1) This permit is being issued for temporary shoring up of the roof. A separate permit must be applied for in the future to permanently repair the roof.				
<b>Dept:</b> Building <b>Status:</b> Approved w/Conditions <b>Reviewer:</b> Jeanie Bourke <b>Approval Date:</b> 02/25/2015 <b>Note:</b> <b>Ok to Issue:</b> <input checked="" type="checkbox"/> <b>Conditions:</b> 1) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
<b>Dept:</b> Fire <b>Status:</b> Not Applicable <b>Reviewer:</b> Jeanie Bourke <b>Approval Date:</b> 02/25/2015 <b>Note:</b> <b>Ok to Issue:</b> <input checked="" type="checkbox"/> <b>Conditions:</b>				