CITY OF PORTLAND, MAINE
RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 04/27/15

NB SER. NO. 1136229

CERTIFIED BY: QUALITY STEEL CORPORATION

CLEVELAND, MS - FREMONT, OH - WEST JORDAN, UT

MAX. ALLOW. WORK. PRESS. 250 PSI AT [illegible] °F.

M.D.M.T. -20 °F. AT 250 PSI

W.
U RT4

YEAR BUILT 2015

CRN NO. L-4709.5C

SER. NO. 1136229

LENGTH 120 IN. OUTSIDE DIA. [illegible] IN.

HEAD THK. [illegible] IN. SHELL THK. .218 IN.

ABOVE
GROUND TYPE [illegible] SURFACE AREA [illegible] SQ. FT.

LISTED CONTAINER
ASSEMBLY FOR LP GAS
547P

HEAD D.R. HEMI.

WATER CAPACITY 500 GALLONS

THIS CONTAINER SHALL NOT CONTAIN A PRODUCT
HAVING A VAPOR PRESSURE IN EXCESS OF 215 PSI AT 100°F.

DIP TUBE LENGTH - 80% FULL AT 40°F. D.T.= [illegible] IN.