Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 04/27/15

mtu onsite energy

MODEL: GG04RG075V1M00004

SERIAL: 94110600245

RATING: STANDBY SERVICE

ENGINE: GM 4.3L

RPM: 1800 Hz: 60

kW: 30 kVA: 30

VOLTAGE	AMPS	PH	PF
120/240	125	1	1.0

WIRE CONFIG: Double Delta

TEMP. RISE / AMB. (°C): 105 / 40

	FUEL TYPE	INLET PRESSURE (in H_2O)	MAX. INPUT (Btu/H)	MAX. INLET FLOW
	NATURAL GAS	7-11	489000	489 ft^3/h @ 1000 Btu/ft^3
X	LP GAS	7-11	540000	216 ft^3/h @ 2500 Btu/ft^3
	LP LIQUID	7-11	540000	5.9 gal/h @ 91500 Btu/gal

www.mtuonsiteenergy.com

UL LISTED

STATIONARY ENGINE GENERATOR ASSEMBLY 4DA1

FILE AU3559

CSA 169106 ELECTRICAL SAFETY ONLY

Mfg. Date 11/14