

EBPS10A BATTERY CALCULATIONS

SYSTEM PARAMETERS

STANDBY TIME 24 HOURS  
 ALARM TIME 15 MINUTES  
 WIRE DISTANCE SAFETY FACTOR 20%  
 BATTERY DERATING FACTOR 125%  
 WIRING STYLE B

COMPONENTS	STANDBY	ALARM	WIRE SIZE (AWG SOLID)	OHMS/KFT
EBPS6A	0.07	0.27		
NAC 1	0	1.488	14	3.14
NAC 2	0	1.51	14	3.14
NAC 3	0	1.396	14	3.14
NAC 4	0	1.116	14	3.14
AUX	0	0		
TOTAL AMPS (ON AC)	0	5.51		
TOTAL AMPS (ON BATTERY)	0.07	5.78		
STANDBY & ALARM TIME (HRS)	24	0.25		
AH REQUIRED	1.68	1.445		
TOTAL AH REQUIRED	3.125	AH		
BATTERY DERATING FACTOR	125%			
MINIMUM AH REQUIRED	3.906	AH		

BATTERIES TO BE INSTALLED	7 AH
---------------------------	------