

EBPS10A BATTERY CALCULATIONS

SYSTEM PARAMETERS

STANDBY TIME 24 HOURS  
 ALARM TIME 15 MINUTES  
 WIRE DISTANCE SAFETY FACTOR 20%  
 BATTERY DERATING FACTOR 125%  
 WIRING STYLE B

COMPONENTS	STANDBY	ALARM	WIRE SIZE (AWG SOLID)	OHMS/KFT
EBPS6A	0.07	0.27		
NAC 1	0	1.151	14	3.19
NAC 2	0	1.293	14	3.19
NAC 3	0	1.342	14	3.19
NAC 4	0	1.062	14	3.19
AUX	0	0		
TOTAL AMPS (ON AC)	0	4.848		
TOTAL AMPS (ON BATTERY)	0.07	5.118		
STANDBY & ALARM TIME (HRS)	24	0.25		
AH REQUIRED	1.68	1.2795		
TOTAL AH REQUIRED	2.9595	AH		
BATTERY DERATING FACTOR	125%			
MINIMUM AH REQUIRED	3.699	AH		

BATTERIES TO BE INSTALLED	7	AH
---------------------------	---	----