

## NAC Circuit Voltage Drop Calculation

Project Name	CMP- Portland Service Center		
Date	2/6/2017		
Circuit Number	Nac#15		
Area Covered			
NAC Source Alarm Voltage	19.1	Wire Gauge 14	Resistance Per Kft Cable 3.14
Minimum Device Voltage	16		
Distance to first appliance	35		
Total Circuit Current	1.342		

Wire Gauge for balance of circuit	14	3.14
-----------------------------------	----	------

Circuit is within limits	Device Current	Distance from previous device	Voltage at Device	Drop from source	Percent Drop
Appliance 1	0.125		18.95	0.15	0.8%
Appliance 2	0.125	35	18.82	0.28	1.5%
Appliance 3	0.129	35	18.70	0.40	2.1%
Appliance 4	0.281	50	18.55	0.55	2.9%
Appliance 5	0.151	40	18.46	0.64	3.3%
Appliance 6	0.190	40	18.40	0.70	3.7%
Appliance 7	0.151	40	18.35	0.75	3.9%
Appliance 8	0.190	40	18.33	0.77	4.0%
END			18.33	0.77	4.0%
END			18.33	0.77	4.0%
END			18.33	0.77	4.0%
END			18.33	0.77	4.0%
END			18.33	0.77	4.0%
END			18.33	0.77	4.0%
END			18.33	0.77	4.0%
END			18.33	0.77	4.0%
END			18.33	0.77	4.0%
END			18.33	0.77	4.0%
END			18.33	0.77	4.0%
END			18.33	0.77	4.0%
END			18.33	0.77	4.0%
END			18.33	0.77	4.0%
END			18.33	0.77	4.0%
END			18.33	0.77	4.0%
END			18.33	0.77	4.0%
END			18.33	0.77	4.0%
END			18.33	0.77	4.0%
END			18.33	0.77	4.0%
END			18.33	0.77	4.0%
Totals	1.342	315			

Appliance circuit voltage drop calculations start at "end of battery life" as NAC Source Alarm Voltage and use 20% below nameplate rating for Minimum Appliance Voltage.

Note. Wire resistance is based on the 2014 NEC Table 8 Uncoated DC resistance. All resistance is based on solid conductors