

CITY OF PORTLAND
 FIRE PREVENTION BUREAU
 380 Congress Street, Portland, Maine 04101
 fireprevention@portlandmaine.gov
 (207) 874-8400



NOTICE OF VIOLATION AND ORDER TO CORRECT

May 18, 2017

Responsible Party 1: CENTRAL MAINE POWER CO ONE CITY CENTER 5TH FLOOR PORTLAND, ME 04101		
Location 138 CANCO RD	CBL 148 A006001	Inspection Date 5/4/2017
Inspector Brad James	Inspection Type FP Permit	Status Failed

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose a date of completion to remedy each violation, a final date of completion, and a date of re-inspection.

You must send this form to the Fire Prevention Bureau no later than 6/15/2017.

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

Violation	Proposed Date of Completion
1-4.5.8 MAINTENANCE, INSPECTION, AND TESTING; WHENEVER OR WHEREVER ANY DEVICE, EQUIPMENT, SYSTEM, CONDITION, ARRANGEMENT, LEVEL OF PROTECTION, FIRE-RESISTIVE CONSTRUCTION, OR ANY OTHER FEATURE IS REQUIRED FOR COMPLIANCE WITH THE PROVISIONS OF THIS CODE, SUCH DEVICE, EQUIPMENT, SYSTEM, CONDITION, ARRANGEMENT, LEVEL OF PROTECTION, FIRE-RESISTIVE CONSTRUCTION, OR OTHER FEATURE SHALL THEREAFTER BE CONTINUOUSLY MAINTAINED. Horizontal sliding fire doors in all areas.	
NFPA 101- 9.1.2 CERTIFY ELECTRICAL SYSTEM; Electrical wiring and equipment shall be in accordance with NFPA 70, unless such installations are approved existing installations, which shall be permitted to be continued in service. Electrical panels through the building need to be labeled more accurately.	
FINAL DATE OF COMPLETED VIOLATION(S)	___/___/___
FIRE PREVENTION BUREAU RE-INSPECTION OF COMPLETED VIOLATION(S)	___/___/___

The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.

VIOLATOR CERTIFICATION

I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau's discretion to grant or deny.

I further understand that it is my responsibility to schedule a reinspection of my property once the violations have been remedied to do so. My failure to schedule a reinspection shall be deemed an admission that the violations have not been remedied.

If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.

Date
6/8/17

Responsible Party
Steven J. W. Little

Date

Responsible Party

SEEN AND AGREED

Date

Fire Prevention Bureau