Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 09/18/14

2nd FLOOR

TOTAL BUILDING AREA FIRST FLOOR = 61,820 S.F.
TOTAL BUILDING AREA SECOND FLOOR = 18,231 S.F.

BUILDING TOTAL: 80,051 S.F.

LEGEND

- AREA CURRENTLY OCCUPIED BY CITY OF PORTLAND (POLICE AND FIRE DEPTS & BUILDING TRADES). 31,315 S.F.
  RENOVATION SCOPE:
  - UPGRADES TO FIRE ALARM AND DETECTION TO MEET CURRENT CODE
  - ADDITION OF EMERGENCY LIGHTING AND EXIT SIGNS
  - INSTALLATION OF CO2 EXHAUST SYSTEM
  - INSTALLATION OF FLOOR DRAINS AND OIL SEPERATOR AT WH 3
- AREA OF NEW INTERIOR FIT UP CONSTRUCTION 2,376 S.F.
- AREAS OCCUPIED BY OTHER TENANTS. NO RENOVATION WORK PLANNED
- EXIST'G OFFICE AREA OCCUPIED BY CITY OF PORTLAND NO RENOVATION WORK PLANNED.
- EXIT SIGN/COMB EMERGENCY LIGHT
- FIRE EXTINGUISHER LOCATION (REQUIRED EVERY 75')

City of Portland
Public Facilities
Operation
Center

212 Canco Road
Portland, Maine

REVISIONS

PERMIT DRAWINGS
August 18, 2014

Life Safety Plan